312699

AIR SAMPLING QUALITY ASSURANCE PROJECT PLAN

Sweet Kleen Laundry
760 Kensington Ave.
Buffalo, New York

Prepared by:

Removal Support Team
Weston Solutions, Inc.
Federal Programs Division
Edison, New Jersey 08837

Prepared for:

U.S. Environmental Protection Agency
Region 2 - Removal Action Branch
Edison, New Jersey 08837

DCN #: RST-02-F-01838
TDD #: 02-05-05-0001
EPA Contract No.: 68-W-00-113

Approved by:

RST

M. Mahnkopf

Michael Mahnkopf
Environmental Scientist

Date: 05/05/05

RST

(for)

Smita Sumbaly, RST
Quality Assurance Officer

Date: 5/5/05

EPA

_____

Kevin Matheis
On-Scene Coordinator

Date: _____

TABLE OF CONTENTS

The following elements are provided in the RST Generic Quality Assurance Project Plan (QAPP) and are included by reference:

QA REPORTS TO MANAGEMENT
PREVENTIVE MAINTENANCE PROCEDURES AND SCHEDULES
RECORDS MANAGEMENT SYSTEM
LOGBOOK PROGRAM
QUALITY-RELATED DOCUMENTS
INSPECTION/ACCEPTANCE REQUIREMENTS FOR SUPPLIES AND CONSUMABLES

LIST OF TABLES

LIST OF ATTACHMENTS

ATTACHMENT 1: Site Location Map

ATTACHMENT 2: Asbestos Sampling SOP# 2015

ATTACHMENT 3: NIOSH Method 7400

ATTACHMENT 4: NIOSH Method 7402

1.0 INTRODUCTION

Presented herein is the Air Sampling Quality Assurance Project Plan (QAPP) for the sampling event to be conducted at the Sweet Kleen Laundry site by the Region 2 Removal Support Team (RST). The site QAPP has been developed at the request of the United States Environmental Protection Agency (EPA) in accordance with the RST generic Quality Assurance Project Plan (QAPP).

This plan is based on information currently available and may be modified on site in light of field screening results and other acquired information. All deviations from this QAPP will be noted in the Sampling Trip Report.

2.0 PROJECT DESCRIPTION

On December 16, 2003, EPA and RST conducted a site reconnaissance/inspection at the site. The site is located at 760 Kensington Avenue in Buffalo, Erie County, New York (see Figure 1) and consists of several buildings connected by a courtyard area on approximately 2 acres. The buildings appeared to be structurally sound, however, there were extensive open areas which resulted from roof collapse.

RST conducted a Level B entry into the site building to conduct air monitoring for organic vapors and radiation. The air monitoring results indicated that all parameters monitored were either below or at background levels established prior to site entry in the parking lot area. RST collected bulk samples from different suspected asbestos containing material including pipe insulation and debris material from the south side building area. Analytical results confirmed the presence of asbestos. It was estimated that 1,000 linear feet of pipe insulation exists at various locations throughout the site buildings. The outer diameter of the insulation appeared to range from 3 to 6 inches.

RST also collected drum waste samples for waste disposal analyses (RCRA characteristics and full TCLP). Analytical results indicated that the drum wastes exhibited TCLP tetrachloroethylene concentrations in excess of its RCRA regulatory level of 0.7 mg/l and should be classified as a RCRA hazardous waste (EPA waste code D039).

RST has been tasked to perform air sampling for asbestos and particulate air monitoring during ACM abatement and building demolition. RST has also been tasked to perform organic vapor air monitoring during drum/container removal.

3.0 PROJECT ORGANIZATION AND RESPONSIBILITIES

The EPA On-Scene Coordinator (OSC), Kevin Matheis, will provide overall direction to the staff concerning project sampling needs, objectives, and schedule. The Site Project Manager (SPM), Aaron Levy will be the primary point of contact with the OSC. The SPM is responsible for the development and completion of the Sampling QA/QC Plan, project team organization, and supervision of all project tasks, including reporting and deliverables. The Site QC Coordinator will be responsible for ensuring field adherence to the Sampling QA/QC Plan and recording of any deviations.

The ERRS contractor, WRS Infrastructure & Environment, Inc. will subcontract to EMSL Analytical, Inc., Depew, New York for the performance of all laboratory analysis.

The following personnel will work on this project:

Personnel	Responsibility
Kevin Matheis	On-Scene Coordinator
Aaron Levy	Site Project Manager, Sample Collection and Management
To Be Determined	Sample Collection and Management

The following laboratory will provide the following analyses:

Lab Name/Location	Sample Type	Parameters
EMSL Analytical, Inc. 490 Rowley Road Depew, NY 14043	Air	Asbestos - Phase Contrast Microscopy (PCM); Asbestos - Transmission Electron Microscopy (TEM)

The OSC has requested 24 hour verbal and two week written analytical turnaround times.

4.0 DATA USE OBJECTIVES, QA OBJECTIVES

In addition to the following, the Data Used Objectives, QA Objectives procedure will be conducted in accordance with Sections A7, B2, B4, and B5 of the Region 2 RST QAPP.

The objective of the asbestos air sampling and particulate monitoring project is to determine the concentrations of asbestos fibers and nuisance dust in exterior air along the site boundary and other background areas during the ACM abatement and building demolition operations. The objective of the organic vapor air monitoring is to ensure no organic vapors are released into the surrounding environment during drum/container removal.

The samples for asbestos will be submitted for phase contrast microscopy (PCM) analysis and, if necessary, transmission electron microscopy (TEM). When PCM analysis indicates a total fiber count above the Occupational Safety and Health Administration (OSHA) permissible exposure limit (PEL) and the National Institute for Occupational Safety and Health (NIOSH) recommended exposure level (REL) of 0.1 fibers/cubic centimeter of air, TEM will be used to identify asbestos fibers from non-asbestos fibers.

4.1 Data Use Objectives

The overall Quality Assurance (QA) objective for chemical measurement data associated with this sampling event is to provide analytical results that are legally defensible in a court of law. The QA program will incorporate Quality Control (QC) procedures for field sampling, chain of custody, laboratory analyses and reporting to assure generation of sound analytical results.

The EPA On-Scene Coordinator (OSC) has specified a level of QA-1 for this sampling event. Details of this QA level are provided below.

4.2 QA Objectives

The QA Protocols for a Level 1 QA objective sampling event are applicable to all sample matrices and include:

1. Sample documentation in the form of field logbooks, appropriate field data sheets, and chain of custody records (chain of custody records are optional for field screening locations).

2. Calibration of all monitoring and/or field-portable analytical equipment prior to collection and analyses of samples with results and/or performance check procedures/methods summarized and documented in a field, personal, and/or instrument log notebook.

3. Field or laboratory determined method detection limits (MDLs) will be recorded along with corresponding analytical sample results, where appropriate.

The objective of this project/event applies to the following parameters:

TABLE 1: QUALITY ASSURANCE OBJECTIVES

QA Parameters	Matrix	Intended Use of Data	QA Objective
Asbestos	Air	Determine the presence or absence of asbestos fibers	QA-1

A Field Sampling Summary is attached in Table 2 and a QA/QC Analysis and Objectives Summary is attached in Table 3. Section 5.1, Sampling Design, provides information on the analyses to be performed.

TABLE 2: FIELD SAMPLING SUMMARY

Analytical Parameters	Matrix	Sample Medium	Preservative	Holding Time	Subtotal Samples	Field Blank	Total Samples **
Asbestos - PCM	Air	0.8 um MCE filter	None	None	5/day	1/day	TBD
Asbestos - TEM	Air	0.8 um MCE filter	None	None	5/day *	1/day	TBD

* = actual number of TEM analyses will be based on results of the PCM analyses. Five samples will be collected daily and held for potential analysis.

** = total number of samples collected will be based on project duration.

TABLE 3: QA/QC ANALYSIS AND OBJECTIVES SUMMARY

MATRIX	ANALYTICAL PARAMETER	Analytical Method Reference	QA/QC Quantitation Limits
Air	Asbestos	NIOSH Method No. 7400 (PCM), modified to include one (1) field blank per day	As per method
Air	Asbestos	NIOSH Method No. 7402 (TEM), modified to include one (1) field blank per day	As per method

5.0 APPROACH AND SAMPLING PROCEDURES

In addition to the following, the approach and sampling procedures will be conducted in accordance with Sections B1 and B4 of the EPA Region 2 RST QAPP.

RST will conduct air sampling, organic vapor monitoring and particulate air monitoring at the Sweet Kleen Laundry site.

This sampling design is based on information currently available and may be modified on site in light of field screening results and other acquired information. All deviations from the sampling plan will be noted in the Sampling Trip Report.

5.1 Sampling Design

RST will conduct outdoor air sampling and particulate monitoring at five perimeter/background locations during an initial three day sample period (May 24-26, 2005) to determine background/baseline concentrations. These sampling locations will be determined in the field and may vary depending on daily site conditions.

Samples collected for asbestos will be collected over an eight hour time period at an approximate flow rate of 2.0 liters per minute. For asbestos, the minimum volume required pursuant to NIOSH Methods 7400/7402 is 400 liters. Additionally, QA/QC samples will include the submission of one field blank per day. A total of six air samples per day will be collected and submitted for laboratory analysis during this initial background sampling episode.

RST will also conduct outdoor air sampling and particulate monitoring at those same locations discussed above during each day of ACM abatement and building demolition operations. Again, sampling locations may vary depending on daily site conditions. A total of six air samples per day will be collected and submitted for laboratory analysis over the duration of site operations.

As stated above in Section 4.0, the samples will be submitted for PCM analysis and, if necessary, TEM. When PCM analysis indicates a total fiber count above the OSHA PEL and the NIOSH REL of 0.1 fibers/cubic centimeter of air, TEM will be used to identify asbestos fibers from non-asbestos fibers.

In addition to air sampling at the above stated locations, total particulate air monitoring will also be performed at each location during the initial background event and during each day of site operations. Organic vapor air monitoring will be performed during drum/container removal operations only.

5.2 Schedule of Activities

Proposed Start Date	Activity	End Date
May 24,2005	Air Sampling and Monitoring	To be determined

5.3 Sampling/Monitoring Equipment

Air samples will be collected utilizing SKC Model 224-PCXR8 sample pumps with 25 mm, three piece cassettes with conductive extension cowl and 0.8 um mixed cellulose ester (MCE) filter. Pump flow rates will be measured (calibrated) before and after sample collection utilizing a BIOS Dry Cell flow meter.

Particulate air monitoring will be performed utilizing MIE DR-4000 Data Rams. Organic vapor monitoring will performed utilizing a RAE Systems MultiRAE Plus Multi-Gas Monitor with PID. Prior to use each day, they will be calibrated in accordance with the manufacturer's instructions.

5.4 Sample Identification System

Each sample collected by Region 2 RST will be designated by a code which will identify the site. The code will be a site-specific project tracking number. The code for the Sweet Kleen Laundry site is *SKL*. Each air sample collected and analyzed for PCM and TEM will be assigned specific numbers as follows.

Example SKL-AAS-01 where:

SKL = Sweet Kleen Laundry;
AAS = Asbestos air sample;
01 = Sample # 1.

5.5 Standard Operating Procedures (SOPs)

5.5.1 Sample Documentation

All sample documents will be completed legibly, in ink. Any corrections or revisions will be made by lining through the incorrect entry and by initialing the error.

FIELD LOGBOOK

The field logbook is essentially a descriptive notebook detailing site activities and observations so that an accurate account of field procedures can be reconstructed in the writer's absence. All entries will be dated and signed by the individuals making the entries, and should include (at a minimum) the following:

1. Site name and project number
2. Name(s) of personnel on site
3. Dates and times of all entries (military time preferred)
4. Descriptions of all site activities, site entry and exit times
5. Noteworthy events and discussions
6. Weather conditions
7. Site observations
8. Sample and sample location identification and description*
9. Subcontractor information and names of on-site personnel
10. Date and time of sample collections, along with chain of custody information
11. Record of photographs
12. Site sketches

* - The description of the sample location will be noted in such a manner as to allow the reader to reproduce the location in the field at a later date.

SAMPLE LABELS

Sample labels will clearly identify the particular sample, and should include the following:

1. Site/project number.
2. Sample identification number.
3. Sample collection date and time.
4. Designation of sample (grab or composite).
5. Sample preservation.
6. Analytical parameters.
7. Name of sampler.

Sample labels will be written in indelible ink and securely affixed to the sample cassette.

CUSTODY SEALS

Custody seals demonstrate that a sample container has not been tampered with, or opened. The individual in possession of the sample(s) will sign and date the seal, affixing it in such a manner that the container cannot be opened without breaking the seal. The name of this individual, along with a description of the sample packaging, will be noted in the field logbook.

5.5.2 Sampling SOPs

The following Sampling SOPs will be used for this project:

1. EPA/ERT SOP No. 2015 - Asbestos Sampling (Attachment 2);

2. NIOSH Method 7400 - Asbestos and other fibers by PCM (Attachment 3);
3. NIOSH Method 7402 - Asbestos by TEM (Attachment 4).

5.5.3 Sample Handling and Shipment

Sample cassettes submitted to the laboratory will be sealed and labeled according to the following protocol. Cassette labels will contain all required information including the site/project code, sample number, time and date of collection, analyses requested, elapsed time, volume and averaged flow rate. Cassettes will be placed in a zip lock plastic bag. The zip lock bag will be secured with a custody seal, placed in the appropriate shipping box and delivered via courier service. All sample documentation will accompany the samples.

5.6 Sample Containers

All sample containers will meet the QA/QC specifications in OSWER Directive 9240.0-05A, "Specifications and Guidance for Contaminant Free Sample Containers".

5.7 Disposal of PPE and Contaminated Sampling Materials

All used PPE and disposable sampling equipment will be placed in trash bags and disposed as part of the ACM abatement/building demolition project.

6.0 SAMPLE CUSTODY

In addition to the following, the Sample Custody procedure will be conducted in accordance with Section B3 of the Region 2 RST QAPP.

A chain of custody record will be maintained from the time the sample is taken to its final deposition. Every transfer of custody must be noted and signed for, and a copy of this record kept by each individual who has signed. When samples (or groups of samples) are not under direct control of the individual responsible for them, they must be stored in a locked container sealed with a custody seal. Specific information regarding custody of the samples projected to be collected on the weekend will be noted in the field logbook.

The chain of custody record should include (at minimum) the following:

1. Sample identification number
2. Sample information
3. Sample location
4. Sample date
5. Name(s) and signature(s) of sampler(s)
6. Signature(s) of any individual(s) with custody of samples

A separate chain of custody form must accompany each shipping container for each daily shipment. The chain of custody form must address all samples in that cooler, but not address samples in any other shipping container. This practice maintains the chain of custody for all samples in case of mis-shipment.

7.0 FIELD INSTRUMENT CALIBRATION AND PREVENTIVE MAINTENANCE

In addition to the following, the Field Instrument and Preventative Maintenance procedure will be conducted in accordance with Section B6 of the Region 2 RST QAPP.

The sampling team is responsible for assuring that a calibration/maintenance log will be brought into the field and maintained for each measuring device. Each log will include at a minimum, where applicable:

- name of device and/or instrument calibrated
- device/instrument serial and/or ID number
- frequency of calibration
- date of calibration
- results of calibration
- name of person performing the calibration
- identification of the calibrant

Equipment to be used each day will be calibrated prior to the commencement of daily activities.

8.0 ANALYTICAL METHODS

Analytical methods to be utilized in the analyses of samples collected during this sampling event are detailed in Table 3.

9.0 DATA REDUCTION, VALIDATION, AND REPORTING

In addition to the following, the Data Reduction, Validation, and Reporting procedure will be conducted in accordance with Sections D1, D2, and D3 of the Region 2 RST QAPP.

9.1 Deliverables

The RST SPM, Aaron Levy, will maintain contact with the EPA OSC, Kevin Matheis to keep him informed about the technical and financial progress of this project. This communication will commence with the issuance of the work assignment and project scoping meeting. Activities under this project will be reported in status and trip reports and other deliverables (e.g., analytical reports, final reports) described herein. Activities will also be summarized in appropriate format for inclusion in monthly and annual reports.

The following deliverables will be provided under this project:

DAILY REPORTS

A daily report will be prepared to provide a detailed accounting of what occurred during each day's sampling and monitoring. The daily report will be prepared with the verbal (preliminary) analytical results from that day's activities. The daily report will be submitted within two days of the receipt of the preliminary analytical results. Information provided will include:

1. maps of sampling locations;
2. weather conditions;
3. particulate monitoring results;
4. asbestos sampling results.

MAPS/FIGURES

Maps depicting site layout, contaminant source areas, and sample locations will be included in the daily reports, as appropriate.

ANALYTICAL REPORT

An analytical report will be prepared by EMSL Analytical, Inc. for samples analyzed under this plan. Information regarding the analytical methods or procedures employed, sample results, QA/QC results, chain of custody documentation, laboratory correspondence, and raw data will be provided within this deliverable.

DATA REVIEW

A review of the data generated under this plan will be undertaken. The assessment of data acceptability or usability will be provided separately, or as part of the analytical report.

9.2 Data Validation

Due to the quality assurance level (QA-1) associated with this project, data validation is not required.

10.0 FIELD QUALITY CONTROL CHECKS AND FREQUENCY

In addition to the following, the Field Quality Control Checks and Frequency procedure will be conducted in accordance with Section B7 of the Region 2 RST QAPP.

This section details the Quality Assurance/Quality Control (QA/QC) requirements for field activities performed during the sampling effort.

QA/QC samples will include the collection of one field blank at the frequency of one per day. Field blanks place a mechanism of control on sample handling, storage and shipment. Field blanks are also indicative of ambient conditions and/or equipment conditions that may potentially affect the quality of the associated samples.

11.0 SYSTEM AUDIT

In addition to the following, the System Audit procedure will be conducted in accordance with Section C1 of the Region 2 RST QAPP.

The Field QA/QC Officer will observe sampling operations and review subsequent analytical results to ensure compliance with the QA/QC requirements of the project/sampling event.

12.0 CORRECTIVE ACTION

In addition to the following, the Corrective Action procedure will be conducted in accordance with Section C1 of the Region 2 RST QAPP.

All provisions will be taken in the field and laboratory to ensure that any problems that may develop will be dealt with as quickly as possible to ensure the continuity of the project/sampling events. Any deviations from this sampling plan will be noted in the final report.

ATTACHMENT 1

Site Location Map



FIGURE 1
SITE LOCATION MAP
SWEET KLEEN LAUNDRY
BUFFALO, NY

US ENVIRONMENTAL PROTECTION AGENCY

REMOVAL SUPPORT TEAM

CONTRACT # 68-W-00-113

EDITED BY: W. HENSPERGER

EPA OSC: K. MATHEIS

SITE PROJECT MANAGER: A. LEVY

FILE: D:\DWG\SWEETKLEEN1

WESTON SOLUTIONS
Restoring Resource Efficiency

Weston Solutions Inc.
FEDERAL PROGRAMS DIVISION

IN ASSOCIATION WITH SCIENTIFIC ENVIRONMENTAL ASSOCIATES, INC.
TERRANEAR TECHNOLOGIES GROUP,
AND INNOVATIVE TECHNOLOGICAL SOLUTIONS INC.

ATTACHMENT 2

EPA/ERT SOP No. 2015 - Asbestos Sampling

ASBESTOS SAMPLING

SOP#: 2015
DATE: 11/17/94
REV. #: 0.0

1.0 SCOPE AND APPLICATION

Asbestos has been used in many commercial products including building materials such as flooring tiles and sheet goods, paints and coatings, insulation, and roofing asphalts. These products and others may be found at hazardous waste sites hanging on overhead pipes, contained in drums, abandoned in piles, or as part of a structure. Asbestos tailing piles from mining operations can also be a source of ambient asbestos fibers. Asbestos is a known carcinogen and requires air sampling to assess airborne exposure to human health. This Standard Operating Procedure (SOP) provides procedures for asbestos air sampling by drawing a known volume of air through a mixed cellulose ester (MCE) filter. The filter is then sent to a laboratory for analysis. The U.S. Environmental Protection Agency/Environmental Response Team (U.S. EPA/ERT) uses one of four analytical methods for determining asbestos in air. These include: U.S. EPA's Environmental Asbestos Assessment Manual, Superfund Method for the Determination of Asbestos in Ambient Air for Transmission Electron Microscopy (TEM)[1]; U.S. EPA's Modified Yamate Method for TEM[2]; National Institute for Occupational Safety and Health (NIOSH) Method 7402 (direct method only) for TEM; and NIOSH Method 7400 for Phase Contrast Microscopy (PCM)[3]. Each method has specific sampling and analytical requirements (i.e., sample volume and flow rate) for determining asbestos in air.

The U.S. EPA/ERT typically follows procedures outlined in the TEM methods for determining mineralogical types of asbestos in air and for distinguishing asbestos from non-asbestos minerals. The Phase Contrast Microscopy (PCM) method is used by U.S. EPA/ERT as a screening tool since it is less costly than TEM. PCM cannot distinguish asbestos from non-asbestos fibers, therefore the TEM method may be necessary to confirm analytical results. For example, if an action level for the presence of fibers has been set and PCM analysis indicates that the action level has been exceeded, then TEM analysis can be used to quantify and identify asbestos structures through examination of their morphology crystal structures (through electron diffraction), and elemental composition (through energy dispersive X-ray analysis). In this instance samples should be collected for both analyses in side by side sampling trains (some laboratories are able to perform PCM and TEM analysis from the same filter). The Superfund method is designed specifically to provide results suitable for supporting risk assessments at Superfund sites, it is applicable to a wide range of ambient air situations at hazardous waste sites. U.S. EPA's Modified Yamate Method for TEM is also used for ambient air sampling due to high volume requirements. The PCM and TEM NIOSH analytical methods require lower sample volumes and are typically used indoors; however, ERT will increase the volume requirement for outdoor application.

Other Regulations pertaining to asbestos have been promulgated by U.S. EPA and OSHA. U.S. EPA's National Emission Standards for Hazardous Air Pollutants (NESHAP) regulates asbestos-containing waste materials. NESHAP establishes management practices and standards for the handling of asbestos and emissions from waste disposal operations (40 CFR Part 61, Subparts A and M). U.S. EPA's 40 CFR 763 (July 1, 1987)[4] and its addendum 40 CFR 763 (October 30, 1987)[4] provide comprehensive rules for the asbestos abatement industry. State and local regulations on these issues vary and may be more stringent than federal requirements. The OSHA regulations in 29 CFR 1910.1001 and 29 CFR 1926.58 specify work practices and safety equipment such as respiratory protection and protective clothing when handling asbestos. The OSHA standard for an 8-hour, time-weighted average (TWA) is 0.2 fibers/cubic centimeters of air. This standard pertains to fibers with a length-to-width ratio of 3 to 1 with a fiber length >5 μm[5,6]. An action level of 0.1 fiber/cc (one-half the OSHA standard) is the level U.S. EPA has established in which employers must initiate such activities as air monitoring, employee training, and

medical surveillance[5,6].

These are standard (i.e., typically applicable) operating procedures which may be varied or changed as required, dependent upon site conditions, equipment limitations or limitations imposed by the procedure. In all instances, the ultimate procedures employed should be documented and associated with the final report.

Mention of trade names or commercial products does not constitute U.S. EPA endorsement or recommendation for use.

2.0 METHOD SUMMARY

Prior to sampling, the site should be characterized by identifying on-site as well as off-site sources of airborne asbestos. The array of sampling locations and the schedule for sample collection, is critical to the success of an investigation. Generally, sampling strategies to characterize a single point source are fairly straightforward, while multiple point sources and area sources increase the complexity of the sampling strategy. It is not within the scope of this SOP to provide a generic asbestos air sampling plan. Experience, objectives, and site characteristics will dictate the sampling strategy.

During a site investigation, sampling stations should be arranged to distinguish spatial trends in airborne asbestos concentrations. Sampling schedules should be fashioned to establish temporal trends. The sampling strategy typically requires that the concentration of asbestos at the source (worst case) or area of concern (downwind), crosswind, as well as background (upwind) contributions be quantified. See Table 1 (Appendix A) for U.S. EPA/ERT recommended sampling set up for ambient air. Indoor asbestos sampling requires a different type of strategy which is identified in Table 2 (Appendix A). It is important to establish background levels of contaminants in order to develop a reference point from which to evaluate the source data. Field blanks and lot blanks can be utilized to determine other sources.

Much information can be derived from each analytical method previously mentioned. Each analytical method has specific sampling requirements and produce results which may or may not be applicable to a specific sampling effort. The site sampling objectives should be carefully identified so as to select the most appropriate analytical method. Additionally, some preparation (i.e., lot blanks results) prior to site sampling may be required, these requirements are specified in the analytical methods.

3.0 SAMPLE PRESERVATION, CONTAINERS, HANDLING, AND STORAGE

3.1 Sample Preservation

No preservation is required for asbestos samples.

3.2 Sample Handling, Container and Storage Procedures

1. Place a sample label on the cassette indicating a unique sampling number. Do not put sampling cassettes in shirt or coat pockets as the filter can pick up fibers. The original cassette box is used to hold the samples.

2. Wrap the cassette individually in a plastic sample bag. Each bag should be marked indicating sample identification number, total volume, and date.

3. The wrapped sampling cassettes should be placed upright in a rigid container so that the cassette cap is on top and cassette base is on bottom. Use enough packing material to prevent jostling or damage. Do not use vermiculite as packing material for samples. If possible, hand carry to lab.

4. Provide appropriate documentation with samples (i.e., chain of custody and requested analytical methodology).

4.0 INTERFERENCES AND POTENTIAL PROBLEMS

Flow rates exceeding 16 liters/minute (L/min) which could result in filter destruction due to (a) failure of its physical support under force from the increased pressure drop; (b) leakage of air around the filter mount so that the filter is bypassed, or (c) damage to the asbestos structures due to increased impact velocities.

4.1 U.S. EPA's Superfund Method

4.1.1 Direct-transfer TEM Specimen Preparation Methods

Direct-Transfer TEM specimen preparation methods have the following significant interferences:

- The achievable detection limit is restricted by the particulate density on the filter, which in turn is controlled by the sampled air volume and the total suspended particulate concentration in the atmosphere being sampled.
- The precision of the result is dependent on the uniformity of the deposit of asbestos structures on the sample collection filter.
- Air samples must be collected so that they have particulate and fiber loadings within narrow ranges. If too high a particulate loading occurs on the filter, it is not possible to prepare satisfactory TEM specimens by a direct-transfer method. If too high a fiber loading occurs on the filter, even if satisfactory TEM specimens can be prepared, accurate fiber counting will not be possible.

4.1.2 Indirect TEM Specimen Preparation Methods

Indirect TEM specimen preparation methods have the following interferences:

- The size distribution of asbestos structures is modified.
- There is increased opportunity for fiber loss or introduction of extraneous contamination.
- When sample collection filters are ashed, any fiber contamination in the filter medium is concentrated on the TEM specimen grid.

It can be argued that direct methods yield an under-estimate of the asbestos structure concentration because many of the asbestos fibers present are concealed by other particulate material with which they are associated. Conversely, indirect methods can be considered to yield an over-estimate because some types of complex asbestos structures disintegrate during the preparation, resulting in an increase in the numbers of structures counted.

4.2 U.S. EPA's Modified Yamate Method for TEM

High concentrations of background dust interfere with fiber identification.

4.3 NIOSH Method for TEM

Other amphibole particles that have aspect ratios greater than 3:1 and elemental compositions similar to the asbestos minerals may interfere in the TEM analysis. Some non-amphibole minerals may give electron diffraction patterns similar to amphiboles. High concentrations of background dust interfere with fiber identification.

4.4 NIOSH Method for PCM

PCM cannot distinguish asbestos from non-asbestos fibers; therefore, all particles meeting the counting criteria are counted as total asbestos fibers. Fiber less than 0.25 um in length will not be detected by this method. High levels of non-fibrous dust particles may obscure fibers in the field of view and increase the detection limit.

5.0 EQUIPMENT/MATERIALS

5.1 Sampling Pump

The constant flow or critical orifice controlled sampling pump should be capable of a flow-rate and pumping time sufficient to achieve the desired volume of air sampled.

The lower flow personal sampling pumps generally provide a flow rate of 20 cubic centimeters/minute (cc/min) to 4 L/min. These pumps are usually battery powered. High flow pumps are utilized when flow rates between 2 L/min to 20 L/min are required. High flow pumps are used for short sampling periods so as to obtain the desired sample volume. High flow pumps usually run on AC power and can be plugged into a nearby outlet. If an outlet is not available then a generator should be obtained. The generator should be positioned downwind from the sampling pump. Additional voltage may be required if more than one pump is plugged into the same generator. Several

electrical extension cords may be required if sampling locations are remote.

The recommended volume for the Superfund method (Phase I) requires approximately 20 hours to collect. Such pumps typically draw 6 amps at full power so that 2 lead/acid batteries should provide sufficient power to collect a full sample. The use of line voltage, where available, eliminates the difficulties associated with transporting stored electrical energy.

A stand should be used to hold the filter cassette at the desired height for sampling and the filter cassette shall be isolated from the vibrations of the pump.

5.2 Filter Cassette

The cassettes are purchased with the required filters in position, or can be assembled in a laminar flow hood or clean area. When the filters are in position, a shrink cellulose band or adhesive tape should be applied to cassette joints to prevent air leakage.

5.2.1 TEM Cassette Requirements

Commercially available field monitors, comprising 25 mm diameter three-piece cassettes, with conductive extension cowls shall be used for sample collection. The cassette must be new and not previously used. The cassette shall be loaded with an MCE filter of pore size 0.45 µm, and supplied from a lot number which has been qualified as low background for asbestos determination. The cowls should be constructed of electrically conducting material to minimize electrostatic effects. The filter shall be backed by a 5 µm pore size MCE filter (Figure 1, Appendix B).

5.2.2 PCM Cassette Requirements

NIOSH Method 7400, PCM involves using a 0.8 to 1.2 µm mixed cellulose ester membrane, 25 mm diameter, 50 mm conductive cowl on cassette (Figure 2, Appendix B). Some labs are able to perform PCM and TEM analysis on the same filter; however, this should be discussed with the laboratory prior to sampling.

5.3 Other Equipment

- Inert tubing with glass cyclone and hose barb
- Whirlbags (plastic bags) for cassettes
- Tools - small screw drivers
- Container - to keep samples upright
- Generator or electrical outlet (may not be required)
- Extension cords (may not be required)
- Multiple plug outlet
- Sample labels
- Air data sheets
- Chain of Custody records

6.0 REAGENTS

Reagents are not required for the preservation of asbestos samples.

7.0 PROCEDURES

7.1 Air Volumes and Flow Rates

Sampling volumes are determined on the basis of how many fibers need to be collected for reliable measurements. Therefore, one must estimate how many airborne fibers may be in the sampling location.

Since the concentration of airborne aerosol contaminants will have some effect on the sample, the following is a suggested criteria to assist in selecting a flow rate based on real-time aerosol monitor (RAM) readings in milligrams/cubic meter (mg/m^3).

	Concentration	Flow Rate
• Low RAM readings:	<6.0 mg/m^3	11-15. L/min
• Medium RAM readings:	>6.0 mg/m_3	7.5 L/min
• High RAM readings:	>10. mg/m^3	2.5 L/min

In practice, pumps that are available for environmental sampling at remote locations operate under a maximum load of approximately 12 L/min.

7.1.1 U.S. EPA's Superfund Method

The Superfund Method incorporates an indirect preparation procedure to provide flexibility in the amount of deposit that be can be tolerated on the sample filter and to allow for the selective concentration of asbestos prior to analysis. To minimize contributions to background contamination from asbestos present in the plastic matrices of membrane filters while allowing for sufficient quantities of asbestos to be collected, this method also requires the collection of a larger volume of air per unit area of filter than has traditionally been collected

for asbestos analysis. Due to the need to collect large volumes of air, higher sampling flow rates are recommended in this method than have generally been employed for asbestos sampling in the past. As an alternative, samples may be collected over longer time intervals. However, this restricts the flexibility required to allow samples to be collected while uniform meteorological conditions prevail.

The sampling rate and the period of sampling should be selected to yield as high a sampled volume as possible, which will minimize the influence of filter contamination. Wherever possible, a volume of 15 cubic meters (15,000 L) shall be sampled for those samples intended for analysis only by the indirect TEM preparation method (Phase 1 samples). For those samples to be prepared by both the indirect and the direct specimen preparation methods (Phase 2 samples), the volumes must be adjusted so as to provide a suitably-loaded filter for the direct TEM preparation method. One option is to collect filters at several loadings to bracket the estimated optimum loading for a particular site. Such filters can be screened in the laboratory so that only those filters closest to optimal loading are analyzed. It has been found that the volume cannot normally exceed 5 cubic meters (5000 L) in an urban or agricultural area, and 10 cubic meters (10,000 L) in a rural area for samples collected on a 25 mm filter and prepared by a direct-transfer technique.

An upper limit to the range of acceptable flow rates for this method is 15 L/min. At many locations, wind patterns exhibit strong diurnal variations. Therefore, intermittent sampling (sampling over a fixed time interval repeated over several days) may be necessary to accumulate 20 hours of sampling time over constant wind conditions. Other sampling objectives also may necessitate intermittent sampling. The objective is to design a sampling schedule so that samples are collected under uniform conditions throughout the sampling interval. This method provides for such options. Air volumes collected on Phase I samples are maximized (<16 L/min). Air volumes collected on Phase 2 samples are limited to provide optimum loading for filters to be prepared by a direct-transfer procedure.

7.1.2 U.S. EPA's Modified Yamate Method for TEM

U.S. EPA's TEM method requires a minimum volume of 560 L and a maximum volume of 3,800 L in order to obtain an analytical sensitivity of 0.005 structures/cc. The optimal volume for TEM is 1200 L to 1800 L. These volumes are determined using a 200 mesh EM grid opening with a 25-mm filter cassette. Changes in volume would be necessary if a 37-mm filter cassette is used since the effective area of a 25 mm (385 sq mm) and 37 mm (855 sq m) differ.

7.1.3 NIOSH Method for TEM and PCM

The minimum recommended volume for TEM and PCM is 400 L at 0.1 fiber/cc. Sampling time is adjusted to obtain optimum fiber loading on the filter. A sampling rate of 1 to 4 L/min for eight hours (700 to 2800 L) is appropriate in non-dusty atmospheres containing 0.1 fiber/cc. Dusty atmospheres i.e., areas with high levels of asbestos, require smaller sample volumes (<400 L) to obtain countable samples.

In such cases, take short, consecutive samples and average the results over the total collection time. For documenting episodic exposures, use high flow rates (7 to 16 L/min) over shorter sampling times. In relatively clean atmospheres where targeted fiber concentrations are much less than 0.1 fiber/cc, use larger sample volumes (3,000 to 10,000 L) to achieve quantifiable loadings. Take care, however, not to overload the filter with background dust. If > 50% of the filter surface is covered with particles, the filter may be too overloaded to count and will bias the measured fiber concentration. Do not exceed 0.5 mg total dust loading on the filter.

7.2 Calibration Procedures

In order to determine if a sampling pump is measuring the flow rate or volume of air correctly, it is necessary to calibrate the instrument. Sampling pumps should be calibrated immediately before and after each use. Preliminary calibration should be conducted using a primary calibrator such as a soap bubble type calibrator, (e.g., a Buck Calibrator, Gilibrator, or equivalent primary calibrator) with a representative filter cassette installed between the pump and the calibrator. The representative sampling cassette can be reused for calibrating other pumps that will be used for asbestos sampling. The same cassette lot used for sampling should also be used for the calibration. A sticker should be affixed to the outside of the extension cowl marked "Calibration Cassette."

A rotameter can be used provided it has been recently precalibrated with a primary calibrator. Three separate constant flow calibration readings should be obtained both before sampling and after sampling. Should the flow rate change by more than 5% during the sampling period, the average of the pre- and post-calibration rates will be used to calculate the total sample volume. The sampling pump used shall provide a non-fluctuating air-flow through the filter, and shall maintain the initial volume flow-rate to within ± 10% throughout the sampling period. The mean value of these flow-rate measurements shall be used to calculate the total air volume sampled. A constant flow or critical orifice controlled pump meets these requirements. If at any time the measurement indicates that the flow-rate has decreased by more than 30%, the sampling shall be terminated. Flexible tubing is used to connect the filter cassette to the sampling pump.Sampling pumps can be calibrated prior to coming on-site so that time is saved when performing on-site calibration.

7.2.1 Calibrating a Personal Sampling Pump with an Electronic Calibrator

1. See Manufacturer's manual for operational instructions.

2. Set up the calibration train as shown in (Figure 3, Appendix B) using a sampling pump, electronic calibrator, and a representative filter cassette. The same lot sampling cassette used for sampling should also be used for calibrating.

3. To set up the calibration train, attach one end of the PVC tubing (approx. 2 foot) to the cassette base; attach the other end of the tubing to the inlet plug on the pump. Another piece of tubing is attached from the cassette cap to the electronic calibrator.

4. Turn the electronic calibrator and sampling pump on. Create a bubble at the bottom of the flow chamber by pressing the bubble initiate button. The bubble should rise to the top of the flow chamber. After the bubble runs its course, the flow rate is shown on the LED display.

5. Turn the flow adjust screw or knob on the pump until the desired flow rate is attained.

6. Perform the calibration three times until the desired flow rate of ± 5% is attained.

7.2.2 Calibrating a Rotameter with an Electronic Calibrator

1. See manufacturer's manual for operational instructions.

2. Set up the calibration train as shown in (Figure 4, Appendix B) using a sampling pump, rotameter, and electronic calibrator.

3. Assemble the base of the flow meter with the screw provided and tighten in place. The flow meter should be mounted within 6° vertical.

4. Turn the electronic calibrator and sampling pump on.

5. Create a bubble at the bottom of the flow chamber by pressing the bubble initiate button. The bubble should rise to the top of the flow chamber. After the bubble runs its course, the flow rate is shown on the LED display.

6. Turn the flow adjust screw or knob on the pump until the desired flow rate is attained.

7. Record the electronic calibrator flow rate reading and the corresponding rotameter reading. Indicate these values on the rotameter (sticker). The rotameter should be able to work within the desired flow range. Readings can also be calibrated for 10 cm^3 increments for Low Flow rotameters, 500 cm^3 increments for medium flow rotameters and 1 liter increments for high flow rotameters.

8. Perform the calibration three times until the desired flow rate of ± 5% is attained. Once on site, a secondary calibrator, i.e., rotameter may be used to calibrate sampling pumps.

7.2.3 Calibrating a Personal Sampling Pump with a Rotameter

1. See manufacturer's manual for Rotameter's Operational Instructions.

2. Set up the calibration train as shown in (Figure 5, Appendix B) using a rotameter, sampling pump, and a representative sampling cassette.

3. To set up the calibration train, attach one end of the PVC tubing (approx. 2 ft) to the cassette base; attach the other end of the tubing to the inlet plug on the pump. Another piece of tubing is attached from the cassette cap to the rotameter.

4. Assemble the base of the flow meter with the screw provided and tighten in place. The flow meter should be mounted within 6° vertical.

5. Turn the sampling pump on.

6. Turn the flow adjust screw (or knob) on the personal sampling pump until the float ball on the rotameter is lined up with the precalibrated flow rate value. A sticker on the rotameter should indicate this value.

7. A verification of calibration is generally performed on-site in the clean zone immediately prior to the sampling.

7.3. Meteorology

It is recommended that a meteorological station be established. If possible, sample after two to three days of dry weather and when the wind conditions are at 10 mph or greater. Record wind speed, wind direction, temperature, and pressure in a field logbook. Wind direction is particularly important when monitoring for asbestos downwind from a fixed source.

7.4 Ambient Sampling Procedures

7.4.1 Pre-site Sampling Preparation

1. Determine the extent of the sampling effort, the sampling methods to be employed, and the types and amounts of equipment and supplies needed.

2. Obtain necessary sampling equipment and ensure it is in working order and fully charged (if necessary).

3. Perform a general site survey prior to site entry in accordance with the site specific Health and Safety plan.

4. Once on-site the calibration is performed in the clean zone. The calibration procedures are listed in Section 7.2.

5. After calibrating the sampling pump, mobilize to the sampling location.

7.4.2. Site Sampling

1. To set up the sampling train, attach the air intake hose to the cassette base. Remove the cassette cap (Figure 6 and 7, Appendix B). The cassette should be positioned downward, perpendicular to the wind

2. If AC or DC electricity is required then turn it on. If used, the generator should be placed 10 ft. downwind from the sampling pump.

3. Record the following in a field logbook: date, time, location, sample identification number, pump number, flow rate, and cumulative time.

4. Turn the pump on. Should intermittent sampling be required, sampling filters must be covered between active periods of sampling. To cover the sample filter: turn the cassette to face upward, place the cassette cap on the cassette, remove the inlet plug from the cassette cap, attach a rotameter to the inlet opening of the cassette cap to measure the flow rate, turn off the sampling pump, place the inlet plug into the inlet opening on the cassette cap. To resume sampling: remove the inlet plug, turn on the sampling pump, attach a rotameter to measure the flow rate, remove the cassette cap, replace the inlet plug in the cassette cap and invert the cassette, face downward and perpendicular to the wind.

5. Check the pump at sampling midpoint if sampling is longer than 4 hours. The generators may need to be regased depending on tank size. If a filter darkens in appearance or if loose dust is seen in the filter, a second sample should be started.

6. At the end of the sampling period, orient the cassette up, turn the pump off.

7. Check the flow rate as shown in Section 7.2.3. When sampling open-faced, the sampling cap should be replaced before post calibrating. Use the same cassette used for sampling for post calibration (increase dust/fiber loading may have altered the flow rate.

8. Record the post flow rate.

9. Record the cumulative time or run.

10. Remove the tubing from the sampling cassette. Still holding the cassette upright, replace the inlet plug on the cassette cap and the outlet plug on the cassette base.

7.4.3. Post Site Sampling

1. Follow handling procedures in Section 3.2, steps 1-4.

2. Obtain an electronic or hard copy of meteorological data which occurred during the sampling event. Record weather: wind speed, ambient temperature, wind direction, and precipitation. Obtaining weather data several days prior to the sampling event can also be useful.

7.5 Indoor Sampling Procedures

PCM analysis is used for indoor air samples. When analysis shows total fiber count above the OSHA action level 0.1 f/cc then TEM (U.S. EPA's Modified Yamate Method) is used to identify asbestos from non-asbestos fibers.

Sampling pumps should be placed four to five feet above ground level away from obstructions that may influence air flow. The pump can be placed on a table or counter. Refer to Table 2 (Appendix A) for a summary of indoor sampling locations and rationale for selection.

Indoor sampling utilizes high flow rates to increased sample volumes (2000 L for PCM and 2800 to 4200 L for TEM) in order to obtain lower detection limits below the standard, (i.e., 0.01 f/cc or lower [PCM] and 0.005 structures/cc or lower [TEM]).

7.5.1 Aggressive Sampling Procedures

Sampling equipment at fixed locations may fail to detect the presence of asbestos fibers. Due to limited air movement, many fibers may settle out of the air onto the floor and other surfaces and may not be captured on the filter. In the past, an 8-hour sampling period was recommended to cover various air circulation conditions. A quicker and more effective way to capture asbestos fibers is to circulate the air artificially so that the fibers remain airborne during sampling. The results from this sampling option typifies worst case condition. This is referred to as aggressive air sampling for asbestos. Refer to Table 2 for sample station locations.

1. Before starting the sampling pumps, direct forced air (such as a 1-horsepower leaf blower or large fan) against walls, ceilings, floors, ledges, and other surfaces in the room to initially dislodge fibers from surfaces. This should take at least 5 minutes per 1000 sq. ft. of floor.

2. Place a 20-inch fan in the center of the room. (Use one fan per 10,000 cubic feet of room space.) Place the fan on slow speed and point it toward the ceiling.

3. Follow procedures in Section 7.4.1 and 7.4.2 (Turn off the pump and then the fan(s) when sampling is complete.).

4. Follow handling procedures in Section 3.2, steps 1-4.

8.0 CALCULATIONS

The sample volume is calculated from the average flow rate of the pump multiplied by the number of minutes the pump was running (volume = flow rate X time in minutes). The sample volume should be submitted to the laboratory and identified on the chain of custody for each sample (zero for lot, field and trip blanks).

The concentration result is calculated using the sample volume and the numbers of asbestos structures reported after the application of the cluster and matrix counting criteria.

9.0 QUALITY ASSURANCE/ QUALITY CONTROL

Follow all QA/QC requirements from the laboratories as well as the analytical methods.

9.1 TEM Requirements

1. Examine lot blanks to determine the background asbestos structure concentration.

2. Examine field blanks to determine whether there is contamination by extraneous asbestos structures during specimen preparation.

3. Examine of laboratory blanks to determine if contamination is being introduced during critical phases of the laboratory program.

4. To determine if the laboratory can satisfactorily analyze samples of known asbestos structure concentrations, reference filters shall be examined. Reference filters should be maintained as part of the laboratory's Quality Assurance program.

5. To minimize subjective effects, some specimens should be recounted by a different microscopist.

6. Asbestos laboratories shall be accredited by the National Voluntary Laboratory Accreditation Program.

7. At this time, performance evaluation samples for asbestos in air are not available for Removal Program Activities.

9.2 PCM Requirements

1. Examine reference slides of known concentration to determine the analyst's ability to satisfactorily count fibers. Reference slides should be maintained as part of the laboratory's quality assurance program.

2. Examine field blanks to determine if there is contamination by extraneous structures during sample handling.

3. Some samples should be relabeled then submitted for counting by the same analyst to determine possible bias by the analyst.

4. Participation in a proficiency testing program such as the AIHA-NIOSH proficiency analytical testing (PAT) program.

10.0 DATA VALIDATION

Results of quality control samples will be evaluated for contamination. This information will be utilized to qualify the environmental sample results accordingly with the project's data quality objectives.

11.0 HEALTH AND SAFETY

When working with potentially hazardous materials, follow U.S. EPA, OSHA, and corporate health and safety procedures. More specifically, when entering an unknown situation involving asbestos, a powered air purifying respirator (PAPR) (full face-piece) is necessary in conjunction with HEPA filter cartridges. See applicable regulations for action level, PEL, TLV, etc. If previous sampling indicates asbestos concentrations are below personal health and safety levels, then Level D personal protection is adequate.

12.0 REFERENCES

(1) Environmental Asbestos Assessment Manual, Superfund Method for the Determination of Asbestos in Ambient Air, Part 1: Method, EPA/540/2-90/005a, May 1990, and Part 2: Technical Background Document, EPA/540/2-90/005b, May 1990.

(2) Methodology for the Measurement of Airborne Asbestos by Electron Microscopy, EPA's Report No. 68-02-3266, 1984, G. Yamate, S.C. Agarwal, and R. D. Gibbons.

(3) National Institute for Occupational Safety and Health. NIOSH Manual of Analytical Method. Third Edition. 1987.

(4) U.S. Environmental Protection Agency. Code of Federal Regulations 40 CFR 763. July 1, 1987. Code of Federal Regulations 40 CFR 763 Addendum. October 30, 1987.

(5) U.S. Environmental Protection Agency. Asbestos-Containing Materials in Schools; Final Rule and Notice. 52 FR 41826.

(6) Occupational Safety and Health Administration. Code of Federal Regulations 29 CFR 1910.1001. Washington, D.C. 1987.

APPENDIX A

Tables

TABLE 1.

SAMPLE STATIONS FOR OUTDOOR SAMPLING

Sample Station Location	Sample Numbers	Rationale
Upwind/Background[1]	Collect a minimum of two simultaneous upwind/background samples 30° apart from the prevailing windlines.	Establishes background fiber levels.
Downwind	Deploy a minimum of 3 sampling stations in a 180 degree arc downwind from the source.	Indicates if asbestos is leaving the site.
Site Representative and/or Worst Case	Obtain one site representative sample which shows average condition on-site or obtain worst case sample (optional).	Verify and continually confirm and document selection of proper levels of worker protection.

[1] More than one background station may be required if the asbestos originates from different sources.

APPENDIX A (Cont'd)

Tables

TABLE 2

SAMPLE STATIONS FOR INDOOR SAMPLING

Sample Station Location	Sample Numbers	Rationale
Indoor Sampling	If a work site is a single room, disperse 5 samplers throughout the room. If the work site contains up to 5 rooms, place at least one sampler in each room. If the work site contains more than 5 rooms, select a representative sample of the rooms.	Establishes representative samples from a homogeneous area.
Upwind/Background	If outside sources are suspected, deploy a minimum of two simultaneous upwind/background samples 30° apart from the prevailing windlines.	Establish whether indoor asbestos concentrations are coming from an outside source.
Worst Case	Obtain one worst case sample, i.e., aggressive sampling (optional).	Verify and continually confirm and document selection of proper levels of worker protection.

APPENDIX B

Figures

FIGURE 1. Transmission Electron Microscopy Filter Cassette



APPENDIX B (Cont'd)

Figures

FIGURE 2. Phase Contrast Microscopy Filter Cassette



APPENDIX B (Cont'd)

Figures

FIGURE 3. Calibrating a Personal Sampling Pump with a Bubble Meter



APPENDIX B (Cont'd)

Figures

FIGURE 4. Calibrating a Rotameter with a Bubble Meter



APPENDIX B (Cont'd)

Figures

FIGURE 5. Calibrating a Sampling Pump with a Rotameter



APPENDIX B (Cont'd)

Figures

FIGURE 6. Personal Sampling Train for Asbestos



APPENDIX B (Cont'd)

Figures

FIGURE 7. High Flow Sampling Train for Asbestos



ATTACHMENT 3

NIOSH Method 7400

ASBESTOS and OTHER FIBERS by PCM 7400

Various MW: Various CAS: Various RTECS: Various

METHOD: 7400, Issue 2 **EVALUATION: FULL** **Issue 1: Rev. 3 on 15 May 1989**
Issue 2: 15 August 1994

OSHA : 0.1 asbestos fiber (> 5 µm long)/cc; 1 f/cc/30 min excursion; carcinogen
MSHA: 2 asbestos fibers/cc
NIOSH: 0.1 f/cc (fibers > 5 µm long)/400 L; carcinogen
ACGIH: 0.2 crocidolite; 0.5 amosite; 2 chrysotile and other asbestos, fibers/cc; carcinogen

PROPERTIES: solid, fibrous, crystalline, anisotropic

SYNONYMS [CAS #]: actinolite **[77536-66-4]** or ferroactinolite **[15669-07-5]**; amosite **[12172-73-5]**; anthophyllite **[77536-67-5]**; chrysotile **[12001-29-5]**; serpentine **[18786-24-8]**; crocidolite **[12001-28-4]**; tremolite **[77536-68-6]**; amphibole asbestos **[1332-21-4]**; refractory ceramic fibers **[142844-00-6]**; fibrous glass.

SAMPLING

SAMPLER: FILTER (0.45- to 1.2-µm cellulose ester membrane, 25-mm; conductive cowl on cassette)

FLOW RATE*: 0.5 to 16 L/min

VOL-MIN*: 400 L @ 0.1 fiber/cc
-MAX*: (step 4, sampling)
*Adjust to give 100 to 1300 fiber/mm^2

SHIPMENT: routine (pack to reduce shock)

SAMPLE STABILITY: stable

BLANKS: 2 to 10 field blanks per set

ACCURACY

RANGE STUDIED: 80 to 100 fibers counted

BIAS: See EVALUATION OF METHOD

OVERALL PRECISION ($\hat{S}_{rT}$): 0.115 to 0.13 [1]

ACCURACY: See EVALUATION OF METHOD

MEASUREMENT

TECHNIQUE: LIGHT MICROSCOPY, PHASE CONTRAST

ANALYTE: fibers (manual count)

SAMPLE PREPARATION: acetone - collapse/triacetin - immersion

COUNTING RULES: described in previous version of this method as "A" rules [1,3]

EQUIPMENT:
1. positive phase-contrast microscope
2. Walton-Beckett graticule (100-µm field of view) Type G-22
3. phase-shift test slide (HSE/NPL)

CALIBRATION: HSE/NPL test slide

RANGE: 100 to 1300 fibers/mm^2 filter area

ESTIMATED LOD: 7 fibers/mm^2 filter area

PRECISION ($\hat{S}_r$): 0.10 to 0.12 [1]; see EVALUATION OF METHOD

APPLICABILITY: The quantitative working range is 0.04 to 0.5 fiber/cc for a 1000-L air sample. The LOD depends on sample volume and quantity of interfering dust, and is <0.01 fiber/cc for atmospheres free of interferences. The method gives an index of airborne fibers. It is primarily used for estimating asbestos concentrations, though PCM does not differentiate between asbestos and other fibers. Use this method in conjunction with electron microscopy (e.g., Method 7402) for assistance in identification of fibers. Fibers < ca. 0.25 µm diameter will not be detected by this method [4]. This method may be used for other materials such as fibrous glass by using alternate counting rules (see Appendix C).

INTERFERENCES: If the method is used to detect a specific type of fiber, any other airborne fiber may interfere since all particles meeting the counting criteria are counted. Chain-like particles may appear fibrous. High levels of non-fibrous dust particles may obscure fibers in the field of view and increase the detection limit.

OTHER METHODS: This revision replaces Method 7400, Revision #3 (date 5/15/89).

REAGENTS:

1. Acetone,* reagent grade.
2. Triacetin (glycerol triacetate), reagent grade.

* See SPECIAL PRECAUTIONS.

EQUIPMENT:

1. Sampler: field monitor, 25-mm, three-piece cassette with ca. 50-mm electrically conductive extension cowl and cellulose ester filter, 0.45- to 1.2-µm pore size, and backup pad.
   NOTE 1: Analyze representative filters for fiber background before use to check for clarity and background. Discard the filter lot if mean is ≥5 fibers per 100 graticule fields. These are defined as laboratory blanks. Manufacturer-provided quality assurance checks on filter blanks are normally adequate as long as field blanks are analyzed as described below.
   NOTE 2: The electrically conductive extension cowl reduces electrostatic effects. Ground the cowl when possible during sampling.
   NOTE 3: Use 0.8-µm pore size filters for personal sampling. The 0.45-µm filters are recommended for sampling when performing TEM analysis on the same samples. However, their higher pressure drop precludes their use with personal sampling pumps.
   NOTE 4: Other cassettes have been proposed that exhibit improved uniformity of fiber deposit on the filter surface, e.g., bellmouthed sampler (Envirometrics, Charleston, SC). These may be used if shown to give measured concentrations equivalent to sampler indicated above for the application.
2. Personal sampling pump, battery or line-powered vacuum, of sufficient capacity to meet flow-rate requirements (see step 4 for flow rate), with flexible connecting tubing.
3. Wire, multi-stranded, 22-gauge; 1", hose clamp to attach wire to cassette.
4. Tape, shrink- or adhesive-.
5. Slides, glass, frosted-end, pre-cleaned, 25 x 75-mm.
6. Cover slips, 22- x 22-mm, No. 1-1/2, unless otherwise specified by microscope manufacturer.
7. Lacquer or nail polish.
8. Knife, #10 surgical steel, curved blade.
9. Tweezers.

EQUIPMENT:

10. Acetone flash vaporization system for clearing filters on glass slides (see ref. [5] for specifications or see manufacturer's instructions for equivalent devices).
11. Micropipets or syringes, 5-µL and 100- to 500-µL.
12. Microscope, positive phase (dark) contrast, with green or blue filter, adjustable field iris, 8 to 10X eyepiece, and 40 to 45X phase objective (total magnification ca. 400X); numerical aperture = 0.65 to 0.75.
13. Graticule, Walton-Beckett type with 100-µm diameter circular field (area = 0.00785 mm2) at the specimen plane (Type G-22). Available from Optometrics USA, P.O. Box 699, Ayer, MA 01432 [phone (508)-772-1700], and McCrone Accessories and Components, 850 Pasquinelli Drive, Westmont, IL 60559 [phone (312) 887-7100].
    NOTE: The graticule is custom-made for each microscope. (see APPENDIX A for the custom-ordering procedure).
14. HSE/NPL phase contrast test slide, Mark II. Available from Optometrics USA (address above).
15. Telescope, ocular phase-ring centering.
16. Stage micrometer (0.01-mm divisions).

SPECIAL PRECAUTIONS: Acetone is extremely flammable. Take precautions not to ignite it. Heating of acetone in volumes greater than 1 mL must be done in a ventilated laboratory fume hood using a flameless, spark- free heat source.

SAMPLING:

1. Calibrate each personal sampling pump with a representative sampler in line.
2. To reduce contamination and to hold the cassette tightly together, seal the crease between the cassette base and the cowl with a shrink band or light colored adhesive tape. For personal sampling, fasten the (uncapped) open-face cassette to the worker's lapel. The open face should be oriented downward.
    NOTE: The cowl should be electrically grounded during area sampling, especially under conditions of low relative humidity. Use a hose clamp to secure one end of the wire (Equipment, Item 3) to the monitor's cowl. Connect the other end to an earth ground (i.e., cold water pipe).
3. Submit at least two field blanks (or 10% of the total samples, whichever is greater) for each set of samples. Handle field blanks in a manner representative of actual handling of associated samples in the set. Open field blank cassettes at the same time as other cassettes just prior to sampling. Store top covers and cassettes in a clean area (e.g., a closed bag or box) with the top covers from the sampling cassettes during the sampling period.
4. Sample at 0.5 L/min or greater [6]. Adjust sampling flow rate, Q (L/min), and time, t (min), to produce a fiber density, E, of 100 to 1300 fibers/mm^2 ($3.85 \cdot 10^4$ to $5 \cdot 10^5$ fibers per 25-mm filter with effective collection area A_c= 385 mm^2) for optimum accuracy. These variables are related to the action level (one-half the current standard), L (fibers/cc), of the fibrous aerosol being sampled by:

$$t = \frac{A_c \cdot E}{Q \cdot L \cdot 10^3}, \text{ min.}$$

NOTE 1: The purpose of adjusting sampling times is to obtain optimum fiber loading on the filter. The collection efficiency does not appear to be a function of flow rate in the range of 0.5 to 16 L/min for asbestos fibers [7]. Relatively large diameter fibers (>3 µm) may exhibit significant aspiration loss and inlet deposition. A sampling rate of 1 to 4 L/min for 8 h is appropriate in atmospheres containing ca. 0.1 fiber/cc in the absence of significant amounts of non-asbestos dust. Dusty atmospheres require smaller sample volumes (≤400 L) to obtain countable samples. In such cases take short, consecutive samples and average the results over the total collection time. For documenting episodic exposures, use high flow rates (7 to 16 L/min) over shorter sampling times. In relatively clean atmospheres, where targeted fiber concentrations are much less than 0.1 fiber/cc, use larger sample volumes (3000 to 10000 L) to achieve quantifiable loadings. Take care, however, not to overload the filter with background dust. If ≥ 50% of the filter surface is covered with particles, the filter may be too overloaded to count and will bias the measured fiber concentration.

NOTE 2: OSHA regulations specify a minimum sampling volume of 48 L for an excursion measurement, and a maximum sampling rate of 2.5 L/min [3].

5. At the end of sampling, replace top cover and end plugs.
6. Ship samples with conductive cowl attached in a rigid container with packing material to prevent jostling or damage.

NOTE: Do not use untreated polystyrene foam in shipping container because electrostatic forces may cause fiber loss from sample filter.

SAMPLE PREPARATION:

NOTE 1: The object is to produce samples with a smooth (non-grainy) background in a medium with refractive index ≤1.46. This method collapses the filter for easier focusing and produces permanent (1 - 10 years) mounts which are useful for quality control and interlaboratory comparison. The aluminum "hot block" or similar flash vaporization techniques may be used outside the laboratory [2]. Other mounting techniques meeting the above criteria may also be used (e.g., the laboratory fume hood procedure for generating acetone vapor as described in Method 7400 - revision of 5/15/85, or the non-permanent field mounting technique used in P&CAM 239 [3,7,8,9]). Unless the effective filtration area is known, determine the area and record the information referenced against the sample ID number [1,9,10,11].

NOTE 2: Excessive water in the acetone may slow the clearing of the filter, causing material to be washed off the surface of the filter. Also, filters that have been exposed to high humidities prior to clearing may have a grainy background.

7. Ensure that the glass slides and cover slips are free of dust and fibers.
8. Adjust the rheostat to heat the "hot block" to ca. 70 °C [2].

NOTE: If the "hot block" is not used in a fume hood, it must rest on a ceramic plate and be isolated from any surface susceptible to heat damage.

9. Mount a wedge cut from the sample filter on a clean glass slide.
   a. Cut wedges of ca. 25% of the filter area with a curved-blade surgical steel knife using a rocking motion to prevent tearing. Place wedge, dust side up, on slide.

   NOTE: Static electricity will usually keep the wedge on the slide.

b. Insert slide with wedge into the receiving slot at base of "hot block". Immediately place tip of a micropipet containing ca. 250 µL acetone (use the minimum volume needed to consistently clear the filter sections) into the inlet port of the PTFE cap on top of the "hot block" and inject the acetone into the vaporization chamber with a slow, steady pressure on the plunger button while holding pipet firmly in place. After waiting 3 to 5 sec for the filter to clear, remove pipet and slide from their ports.
   CAUTION: Although the volume of acetone used is small, use safety precautions. Work in a well-ventilated area (e.g., laboratory fume hood). Take care not to ignite the acetone. Continuous use of this device in an unventilated space may produce explosive acetone vapor concentrations.
c. Using the 5-µL micropipet, immediately place 3.0 to 3.5 µL triacetin on the wedge. Gently lower a clean cover slip onto the wedge at a slight angle to reduce bubble formation. Avoid excess pressure and movement of the cover glass.
   NOTE: If too many bubbles form or the amount of triacetin is insufficient, the cover slip may become detached within a few hours. If excessive triacetin remains at the edge of the filter under the cover slip, fiber migration may occur.
d. Mark the outline of the filter segment with a glass marking pen to aid in microscopic evaluation.
e. Glue the edges of the cover slip to the slide using lacquer or nail polish [12]. Counting may proceed immediately after clearing and mounting are completed.
   NOTE: If clearing is slow, warm the slide on a hotplate (surface temperature 50 °C) for up to 15 min to hasten clearing. Heat carefully to prevent gas bubble formation.

CALIBRATION AND QUALITY CONTROL:

10. Microscope adjustments. Follow the manufacturers instructions. At least once daily use the telescope ocular (or Bertrand lens, for some microscopes) supplied by the manufacturer to ensure that the phase rings (annular diaphragm and phase-shifting elements) are concentric. With each microscope, keep a logbook in which to record the dates of microscope cleanings and major servicing.
    a. Each time a sample is examined, do the following:
       (1) Adjust the light source for even illumination across the field of view at the condenser iris. Use Kohler illumination, if available. With some microscopes, the illumination may have to be set up with bright field optics rather than phase contract optics.
       (2) Focus on the particulate material to be examined.
       (3) Make sure that the field iris is in focus, centered on the sample, and open only enough to fully illuminate the field of view.
    b. Check the phase-shift detection limit of the microscope periodically for each analyst/microscope combination:
       (1) Center the HSE/NPL phase-contrast test slide under the phase objective.
       (2) Bring the blocks of grooved lines into focus in the graticule area.
          NOTE: The slide contains seven blocks of grooves (ca. 20 grooves per block) in descending order of visibility. For asbestos counting the microscope optics must completely resolve the grooved lines in block 3 although they may appear somewhat faint, and the grooved lines in blocks 6 and 7 must be invisible when centered in the graticule area. Blocks 4 and 5 must be at least partially visible but may vary slightly in visibility between microscopes. A microscope which fails to meet these requirements has resolution either too low or too high for fiber counting.
       (3) If image quality deteriorates, clean the microscope optics. If the problem persists, consult the microscope manufacturer.
11. Document the laboratory's precision for each counter for replicate fiber counts.
    a. Maintain as part of the laboratory quality assurance program a set of reference slides to be used on a daily basis [13]. These slides should consist of filter preparations including a range of loadings and background dust levels from a variety of sources including both field and reference samples (e.g., PAT, AAR, commercial samples). The Quality Assurance Officer

should maintain custody of the reference slides and should supply each counter with a minimum of one reference slide per workday. Change the labels on the reference slides periodically so that the counter does not become familiar with the samples.

b. From blind repeat counts on reference slides, estimate the laboratory intra- and intercounter precision. Obtain separate values of relative standard deviation (S_r) for each sample matrix analyzed in each of the following ranges: 5 to 20 fibers in 100 graticule fields, >20 to 50 fibers in 100 graticule fields, and >50 to 100 fibers in 100 graticule fields. Maintain control charts for each of these data files.

NOTE: Certain sample matrices (e.g., asbestos cement) have been shown to give poor precision [9]

12. Prepare and count field blanks along with the field samples. Report counts on each field blank.

NOTE 1: The identity of blank filters should be unknown to the counter until all counts have been completed.

NOTE 2: If a field blank yields greater than 7 fibers per 100 graticule fields, report possible contamination of the samples.

13. Perform blind recounts by the same counter on 10% of filters counted (slides relabeled by a person other than the counter). Use the following test to determine whether a pair of counts by the same counter on the same filter should be rejected because of possible bias: Discard the sample if the absolute value of the difference between the square roots of the two counts (in fiber/mm^2) exceeds 2.77 (X)S_r', where X = average of the square roots of the two fiber counts (in fiber/mm^2) and $S_r' = \frac{S_r}{2}$, where S_r is the intracounter relative standard deviation for the appropriate count range (in fibers) determined in step 11. For more complete discussions see reference [13].

NOTE 1: Since fiber counting is the measurement of randomly placed fibers which may be described by a Poisson distribution, a square root transformation of the fiber count data will result in approximately normally distributed data [13].

NOTE 2: If a pair of counts is rejected by this test, recount the remaining samples in the set and test the new counts against the first counts. Discard all rejected paired counts. It is not necessary to use this statistic on blank counts.

14. The analyst is a critical part of this analytical procedure. Care must be taken to provide a non-stressful and comfortable environment for fiber counting. An ergonomically designed chair should be used, with the microscope eyepiece situated at a comfortable height for viewing. External lighting should be set at a level similar to the illumination level in the microscope to reduce eye fatigue. In addition, counters should take 10-to-20 minute breaks from the microscope every one or two hours to limit fatigue [14]. During these breaks, both eye and upper back/neck exercises should be performed to relieve strain.
15. All laboratories engaged in asbestos counting should participate in a proficiency testing program such as the AIHA-NIOSH Proficiency Analytical Testing (PAT) Program for asbestos and routinely exchange field samples with other laboratories to compare performance of counters.

MEASUREMENT:

16. Center the slide on the stage of the calibrated microscope under the objective lens. Focus the microscope on the plane of the filter.
17. Adjust the microscope (Step 10).

NOTE: Calibration with the HSE/NPL test slide determines the minimum detectable fiber diameter (ca. 0.25 µm) [4].

18. Counting rules: (same as P&CAM 239 rules [1,10,11]: see examples in APPENDIX B).
    a. Count any fiber longer than 5 µm which lies entirely within the graticule area.
       (1) Count only fibers longer than 5 µm. Measure length of curved fibers along the curve.
       (2) Count only fibers with a length-to-width ratio equal to or greater than 3:1.
    b. For fibers which cross the boundary of the graticule field:
       (1) Count as 1/2 fiber any fiber with only one end lying within the graticule area, provided that the fiber meets the criteria of rule a above.

(2) Do not count any fiber which crosses the graticule boundary more than once.
(3) Reject and do not count all other fibers.

c. Count bundles of fibers as one fiber unless individual fibers can be identified by observing both ends of a fiber.
d. Count enough graticule fields to yield 100 fibers. Count a minimum of 20 fields. Stop at 100 graticule fields regardless of count.

19. Start counting from the tip of the filter wedge and progress along a radial line to the outer edge. Shift up or down on the filter, and continue in the reverse direction. Select graticule fields randomly by looking away from the eyepiece briefly while advancing the mechanical stage. Ensure that, as a minimum, each analysis covers one radial line from the filter center to the outer edge of the filter. When an agglomerate or bubble covers ca. 1/6 or more of the graticule field, reject the graticule field and select another. Do not report rejected graticule fields in the total number counted.

NOTE 1: When counting a graticule field, continuously scan a range of focal planes by moving the fine focus knob to detect very fine fibers which have become embedded in the filter. The small-diameter fibers will be very faint but are an important contribution to the total count. A minimum counting time of 15 seconds per field is appropriate for accurate counting.

NOTE 2: This method does not allow for differentiation of fibers based on morphology. Although some experienced counters are capable of selectively counting only fibers which appear to be asbestiform, there is presently no accepted method for ensuring uniformity of judgment between laboratories. It is, therefore, incumbent upon all laboratories using this method to report total fiber counts. If serious contamination from non-asbestos fibers occurs in samples, other techniques such as transmission electron microscopy must be used to identify the asbestos fiber fraction present in the sample (see NIOSH Method 7402). In some cases (i.e., for fibers with diameters >1 µm), polarized light microscopy (as in NIOSH Method 7403) may be used to identify and eliminate interfering non-crystalline fibers [15].

NOTE 3: Do not count at edges where filter was cut. Move in at least 1 mm from the edge.

NOTE 4: Under certain conditions, electrostatic charge may affect the sampling of fibers. These electrostatic effects are most likely to occur when the relative humidity is low (below 20%), and when sampling is performed near the source of aerosol. The result is that deposition of fibers on the filter is reduced, especially near the edge of the filter. If such a pattern is noted during fiber counting, choose fields as close to the center of the filter as possible [5].

NOTE 5: Counts are to be recorded on a data sheet that provides, as a minimum, spaces on which to record the counts for each field, filter identification number, analyst's name, date, total fibers counted, total fields counted, average count, fiber density, and commentary. Average count is calculated by dividing the total fiber count by the number of fields observed. Fiber density (fibers/mm^2) is defined as the average count (fibers/field) divided by the field (graticule) area (mm^2/field).

CALCULATIONS AND REPORTING OF RESULTS

20. Calculate and report fiber density on the filter, E (fibers/mm^2), by dividing the average fiber count per graticule field, F/n_f, minus the mean field blank count per graticule field, B/n_b, by the graticule field area, A_f (approx. 0.00785 mm^2):

$$E = \frac{\left(\frac{F}{n_f} - \frac{B}{n_b}\right)}{A_f}, \text{ fibers/mm}^2.$$

NOTE: Fiber counts above 1300 fibers/mm^2 and fiber counts from samples with >50% of filter area covered with particulate should be reported as "uncountable" or "probably biased." Other fiber counts outside the 100-1300 fiber/mm^2 range should be reported as having "greater than optimal variability" and as being "probably biased."

21. Calculate and report the concentration, C (fibers/cc), of fibers in the air volume sampled, V (L), using the effective collection area of the filter, A_c (approx. 385 mm^2 for a 25-mm filter):

$$C = \frac{(E)(A_c)}{V \cdot 10^3}.$$

NOTE: Periodically check and adjust the value of A_c, if necessary.

22. Report intralaboratory and interlaboratory relative standard deviations (from Step 11) with each set of results.

NOTE: Precision depends on the total number of fibers counted [1,16]. Relative standard deviation is documented in references [1,15-17] for fiber counts up to 100 fibers in 100 graticule fields. Comparability of interlaboratory results is discussed below. As a first approximation, use 213% above and 49% below the count as the upper and lower confidence limits for fiber counts greater than 20 (Fig. 1).

EVALUATION OF METHOD:

A. This method is a revision of P&CAM 239 [10]. A summary of the revisions is as follows:

1. Sampling:
   The change from a 37-mm to a 25-mm filter improves sensitivity for similar air volumes. The change in flow rates allows for 2-m^3 full-shift samples to be taken, providing that the filter is not overloaded with non-fibrous particulates. The collection efficiency of the sampler is not a function of flow rate in the range 0.5 to 16 L/min [10].
2. Sample Preparation Technique:
   The acetone vapor-triacetin preparation technique is a faster, more permanent mounting technique than the dimethyl phthalate/diethyl oxalate method of P&CAM 239 [2,4,10]. The aluminum "hot block" technique minimizes the amount of acetone needed to prepare each sample.
3. Measurement:
   a. The Walton-Beckett graticule standardizes the area observed [14,18,19].
   b. The HSE/NPL test slide standardizes microscope optics for sensitivity to fiber diameter [4,14].
   c. Because of past inaccuracies associated with low fiber counts, the minimum recommended loading has been increased to 100 fibers/mm^2 filter area (a total of 78.5 fibers counted in 100 fields, each with field area = .00785 mm^2.) Lower levels generally result in an overestimate of the fiber count when compared to results in the recommended analytical range [20]. The recommended loadings should yield intracounter S_r in the range of 0.10 to 0.17 [21,22,23].

B. Interlaboratory comparability:
   An international collaborative study involved 16 laboratories using prepared slides from the asbestos cement, milling, mining, textile, and friction material industries [9]. The relative standard deviations (S_r) varied with sample type and laboratory. The ranges were:

	Intralaboratory S_r	Interlaboratory S_r	Overall S_r
AIA (NIOSH A Rules)*	0.12 to 0.40	0.27 to 0.85	0.46
Modified CRS (NIOSH B Rules)**	0.11 to 0.29	0.20 to 0.35	0.25

* Under AIA rules, only fibers having a diameter less than 3 µm are counted and fibers attached to particles larger than 3 µm are not counted. NIOSH A Rules are otherwise similar to the AIA rules.
** See Appendix C.

A NIOSH study conducted using field samples of asbestos gave intralaboratory S_r in the range 0.17 to 0.25 and an interlaboratory S_r of 0.45 [21]. This agrees well with other recent studies [9,14,16].

At this time, there is no independent means for assessing the overall accuracy of this method. One measure of reliability is to estimate how well the count for a single sample agrees with the mean count from a large number of laboratories. The following discussion indicates how this estimation can be carried out based on measurements of the interlaboratory variability, as well as showing how the results of this method relate to the theoretically attainable counting precision and to measured intra- and interlaboratory S_r. (NOTE: The following discussion does not include bias estimates and should not be taken to indicated that lightly loaded samples are as accurate as properly loaded ones).

Theoretically, the process of counting randomly (Poisson) distributed fibers on a filter surface will give an S_r that depends on the number, N, of fibers counted:

$$S_r = 1/(N)^{1/2} \quad (1)$$

Thus S_r is 0.1 for 100 fibers and 0.32 for 10 fibers counted. The actual S_r found in a number of studies is greater than these theoretical numbers [17,19,20,21].

An additional component of variability comes primarily from subjective interlaboratory differences. In a study of ten counters in a continuing sample exchange program, Ogden [15] found this subjective component of intralaboratory S_r to be approximately 0.2 and estimated the overall S_r by the term:

$$\frac{[N + (0.2 \cdot N)^2]^{1/2}}{N} \quad (2)$$

Ogden found that the 90% confidence interval of the individual intralaboratory counts in relation to the means were +2 S_r and - 1.5 S_r. In this program, one sample out of ten was a quality control sample. For laboratories not engaged in an intensive quality assurance program, the subjective component of variability can be higher.

In a study of field sample results in 46 laboratories, the Asbestos Information Association also found that the variability had both a constant component and one that depended on the fiber count [14]. These results gave a subjective interlaboratory component of S_r (on the same basis as Ogden's) for field samples of ca. 0.45. A similar value was obtained for 12 laboratories analyzing a set of 24 field samples [21]. This value falls slightly above the range of S_r (0.25 to 0.42 for 1984-85) found for 80 reference laboratories in the NIOSH PAT program for laboratory-generated samples [17].

A number of factors influence S_r for a given laboratory, such as that laboratory's actual counting performance and the type of samples being analyzed. In the absence of other information, such as from an interlaboratory quality assurance program using field samples, the value for the subjective component of variability is chosen as 0.45. It is hoped that the laboratories will carry out the recommended interlaboratory quality assurance programs to improve their performance and thus reduce the S_r.

The above relative standard deviations apply when the population mean has been determined. It is more useful, however, for laboratories to estimate the 90% confidence interval on the mean count from a single sample fiber count (Figure 1). These curves assume similar shapes of the count distribution for interlaboratory and intralaboratory results [16].

For example, if a sample yields a count of 24 fibers, Figure 1 indicates that the mean interlaboratory count will fall within the range of 227% above and 52% below that value 90% of the time. We can apply these percentages directly to the air concentrations as well. If, for instance, this sample (24 fibers counted) represented a 500-L volume, then the measured concentration is 0.02 fibers/mL (assuming 100 fields counted, 25-mm filter, 0.00785 mm^2 counting field area). If this same sample were counted by a group of laboratories, there is a 90% probability that the mean would fall between 0.01 and 0.08 fiber/mL. These limits should be reported in any comparison of results between laboratories.

Note that the S_r of 0.45 used to derive Figure 1 is used as an estimate for a random group of laboratories. If several laboratories belonging to a quality assurance group can show that their interlaboratory S_r is smaller, then it is more correct to use that smaller S_r. However, the estimated S_r of 0.45 is to be used in the absence of such information. Note also that it has been found that S_r can be higher for certain types of samples, such as asbestos cement [9].

Quite often the estimated airborne concentration from an asbestos analysis is used to compare to a regulatory standard. For instance, if one is trying to show compliance with an 0.5 fiber/mL standard using a single sample on which 100 fibers have been counted, then Figure 1 indicates that the 0.5 fiber/mL standard must be 213% higher than the measured air concentration. This indicates that if one measures a fiber concentration of 0.16 fiber/mL (100 fibers counted), then the mean fiber count by a group of laboratories (of which the compliance laboratory might be one) has a 95% chance of being less than 0.5 fibers/mL; i.e., 0.16 + 2.13 x 0.16 = 0.5.

It can be seen from Figure 1 that the Poisson component of the variability is not very important unless the number of fibers counted is small. Therefore, a further approximation is to simply use +213% and -49% as the upper and lower confidence values of the mean for a 100-fiber count.



Figure 1. Interlaboratory Precision of Fiber Counts

The curves in Figures 1 are defined by the following equations:

$$UCL = \frac{2X + 2.25 + [(2.25 + 2X)^2 - 4(1 - 2.25 S_r^2) X^2]^{1/2}}{2(1 - 2.25 S_r^2)} \quad (3)$$

$$LCL = \frac{2X + 4 - [(4 + 2X)^2 - 4(1 - 4 S_r^2) X^2]^{1/2}}{2(1 - 4 S_r^2)} \quad (4)$$

where S_r = subjective interlaboratory relative standard deviation, which is close to the total interlaboratory S_r when approximately 100 fibers are counted.
X = total fibers counted on sample
LCL = lower 95% confidence limit.
UCL = upper 95% confidence limit.
Note that the range between these two limits represents 90% of the total range.

REFERENCES:

[1] Leidel, N. A., S. G. Bayer, R. D. Zumwalde, and K. A. Busch. USPHS/NIOSH Membrane Filter Method for Evaluating Airborne Asbestos Fibers, U.S. Department of Health, Education, and Welfare, Publ. (NIOSH) 79-127 (1979).

[2] Baron, P. A. and G. C. Pickford. "An Asbestos Sample Filter Clearing Procedure," Appl. Ind. Hyg., 1:169-171, 199 (1986).

[3] Occupational Safety and Health Administration, U.S. Department of Labor, Occupational Exposure to Asbestos, Tremolite, Anthophyllite, and Actinolite Asbestos; Final Rules, 29 CFR Part 1910.1001 Amended June 20, 1986.

[4] Rooker, S. J., N. P. Vaughn, and J. M. LeGuen. "On the Visibility of Fibers by Phase Contrast Microscopy," Amer. Ind. Hyg. Assoc. J., 43, 505-515 (1982).

[5] Baron, P. and G. Deye, "Electrostatic Effects in Asbestos Sampling," Parts I and II Amer. Ind. Hyg. Assoc. J., 51, 51-69 (1990).

[6] Johnston, A. M., A. D. Jones, and J. H. Vincent. "The Influence of External Aerodynamic Factors on the Measurement of the Airborne Concentration of Asbestos Fibers by the Membrane Filter Method," Ann. Occup. Hyg., 25, 309-316 (1982).

[7] Beckett, S.T., "The Effects of Sampling Practice on the Measured Concentration of Airborne Asbestos," Ann. Occup. Hyg., 21, 259-272 (1980).

[8] Jankovic, J. T., W. Jones, and J. Clere. "Field Techniques for Clearing Cellulose Ester Filters Used in Asbestos Sampling," Appl. Ind. Hyg., 1, 145-147 (1986).

[9] Crawford, N. P., H. L. Thorpe, and W. Alexander. "A Comparison of the Effects of Different Counting Rules and Aspect Ratios on the Level and Reproducibility of Asbestos Fiber Counts," Part I: Effects on Level (Report No. TM/82/23), Part II: Effects on Reproducibility (Report No. TM/82/24), Institute of Occupational Medicine, Edinburgh, Scotland (December, 1982).

[10] NIOSH Manual of Analytical Methods, 2nd ed., Vol. 1., P&CAM 239, U.S. Department of Health, Education, and Welfare, Publ. (NIOSH) 77-157-A (1977).

[11] Revised Recommended Asbestos Standard, U.S. Department of Health, Education, and Welfare, Publ. (NIOSH) 77-169 (1976); as amended in NIOSH statement at OSHA Public Hearing, June 21, 1984.

[12] Asbestos International Association, AIA Health and Safety Recommended Technical Method #1 (RTMI). "Airborne Asbestos Fiber Concentrations at Workplaces by Light Microscopy" (Membrane Filter Method), London (1979).

[13] Abell, M., S. Shulman and P. Baron. The Quality of Fiber Count Data, Appl. Ind. Hyg., 4, 273-285

(1989).
[14] "A Study of the Empirical Precision of Airborne Asbestos Concentration Measurements in the Workplace by the Membrane Filter Method," Asbestos Information Association, Air Monitoring Committee Report, Arlington, VA (June, 1983).
[15] McCrone, W., L. McCrone and J. Delly, "Polarized Light Microscopy," Ann Arbor Science (1978).
[16] Ogden, T. L. "The Reproducibility of Fiber Counts," Health and Safety Executive Research Paper 18 (1982).
[17] Schlecht, P. C. and S. A. Schulman. "Performance of Asbestos Fiber Counting Laboratories in the NIOSH Proficiency Analytical Testing (PAT) Program," Am. Ind. Hyg. Assoc. J., 47, 259-266 (1986).
[18] Chatfield, E. J. Measurement of Asbestos Fiber Concentrations in Workplace Atmospheres, Royal Commission on Matters of Health and Safety Arising from the Use of Asbestos in Ontario, Study No. 9, 180 Dundas Street West, 22nd Floor, Toronto, Ontario, CANADA M5G 1Z8.
[19] Walton, W. H. "The Nature, Hazards, and Assessment of Occupational Exposure to Airborne Asbestos Dust: A Review," Ann. Occup. Hyg., 25, 115-247 (1982).
[20] Cherrie, J., A.D. Jones, and A.M. Johnston. "The Influence of Fiber Density on the Assessment of Fiber Concentration Using the membrane filter Method." Am. Ind. Hyg. Assoc. J., 47(8), 465-74 (1986).
[21] Baron, P. A. and S. Shulman. "Evaluation of the Magiscan Image Analyzer for Asbestos Fiber Counting." Am. Ind. Hyg. Assoc. J., (in press).
[22] Taylor, D. G., P. A. Baron, S. A. Shulman and J. W. Carter. "Identification and Counting of Asbestos Fibers," Am. Ind. Hyg. Assoc. J. 45(2), 84-88 (1984).
[23] "Potential Health Hazards of Video Display Terminals," NIOSH Research Report, June 1981.
[24] "Reference Methods for Measuring Airborne Man-Made Mineral Fibers (MMMF)," WHO/EURO Technical Committee for Monitoring an Evaluating Airborne MMMF, World Health Organization, Copenhagen (1985).
[25] Criteria for a Recommended Standard...Occupational Exposure to Fibrous Glass, U.S. Department of Health, Education, and Welfare, Publ. (NIOSH) 77-152 (1977).

METHOD WRITTEN BY:

Paul A. Baron, Ph.D., NIOSH/DPSE.

APPENDIX A: CALIBRATION OF THE WALTON-BECKETT GRATICULE:

Before ordering the Walton-Beckett graticule, the following calibration must be done to obtain a counting area (D) 100 µm in diameter at the image plane. The diameter, d_c (mm), of the circular counting area and the disc diameter must be specified when ordering the graticule.

1. Insert any available graticule into the eyepiece and focus so that the graticule lines are sharp and clear.
2. Set the appropriate interpupillary distance and, if applicable, reset the binocular head adjustment so that the magnification remains constant.
3. Install the 40 to 45X phase objective.
4. Place a stage micrometer on the microscope object stage and focus the microscope on the graduated lines.
5. Measure the magnified grid length of the graticule, L_o (µm), using the stage micrometer.
6. Remove the graticule from the microscope and measure its actual grid length, L_a (mm). This can best be accomplished by using a stage fitted with verniers.
7. Calculate the circle diameter, d_c (mm), for the Walton-Beckett graticule:

$$d_c = \frac{L_a}{L_o} \times D. \qquad (5)$$

Example: If L_o = 112 µm, L_a = 4.5 mm and D = 100 µm, then d_c = 4.02 mm.

8. Check the field diameter, D (acceptable range 100 µm ± 2 µm) with a stage micrometer upon receipt of the graticule from the manufacturer. Determine field area (acceptable range 0.00754 mm^2 to 0.00817 mm^2).

APPENDIX B: COMPARISON OF COUNTING RULES:

Figure 2 shows a Walton-Beckett graticule as seen through the microscope. The rules will be discussed as they apply to the labeled objects in the figure.



Figure 2. Walton-Beckett graticule with fibers.

These rules are sometimes referred to as the "A" rules.

FIBER COUNT

Object	Count	DISCUSSION
1	1 fiber	Optically observable asbestos fibers are actually bundles of fine fibrils. If the fibrils seem to be from the same bundle the object is counted as a single fiber. Note, however, that all objects meeting length and aspect ratio criteria are counted whether or not they appear to be asbestos.
2	2 fiber	If fibers meeting the length and aspect ratio criteria (length >5 µm and length-to-width ratio >3 to 1) overlap, but do not seem to be part of the same bundle, they are counted as separate fibers.
3	1 fiber	Although the object has a relatively large diameter (>3 µm), it is counted as fiber under the rules. There is no upper limit on the fiber diameter in the counting rules. Note that fiber width is measured at the widest compact section of the object.
4	1 fiber	Although long fine fibrils may extend from the body of a fiber, these fibrils are considered part of the fiber if they seem to have originally been part of the bundle.
5	Do not count	If the object is ≤5 µm long, it is not counted.
6	1 fiber	A fiber partially obscured by a particle is counted as one fiber. If the fiber ends emanating from a particle do not seem to be from the same fiber and each end meets the length and aspect ratio criteria, they are counted as separate fibers.
7	1/2 fiber	A fiber which crosses into the graticule area one time is counted as 1/2 fiber.
8	Do not count	Ignore fibers that cross the graticulate boundary more than once. count
9	Do not count	Ignore fibers that lie outside the graticule boundary.

APPENDIX C. ALTERNATE COUNTING RULES FOR NON-ASBESTOS FIBERS

Other counting rules may be more appropriate for measurement of specific non-asbestos fiber types, such as fibrous glass. These include the "B" rules given below (from NIOSH Method 7400, Revision #2, dated 8/15/87), the World Health Organization reference method for man-made mineral fiber [24], and the NIOSH fibrous glass criteria document method [25]. The upper diameter limit in these methods prevents measurements of non-thoracic fibers. It is important to note that the aspect ratio limits included in these methods vary. NIOSH recommends the use of the 3:1 aspect ratio in counting fibers.

It is emphasized that hybridization of different sets of counting rules is not permitted. Report specifically which set of counting rules are used with the analytical results.

"B" COUNTING RULES:

1. Count only ends of fibers. Each fiber must be longer than 5 µm and less than 3 µm diameter.
2. Count only ends of fibers with a length-to-width ratio equal to or greater than 5:1.
3. Count each fiber end which falls within the graticule area as one end, provided that the fiber meets rules 1 and 2 above. Add split ends to the count as appropriate if the split fiber segment also meets the criteria of rules 1 and 2 above.
4. Count visibly free ends which meet rules 1 and 2 above when the fiber appears to be attached to another particle, regardless of the size of the other particle. Count the end of a fiber obscured by another particle if the particle covering the fiber end is less than 3 µm in diameter.
5. Count free ends of fibers emanating from large clumps and bundles up to a maximum of 10 ends (5 fibers), provided that each segment meets rules 1 and 2 above.
6. Count enough graticule fields to yield 200 ends. Count a minimum of 20 graticule fields. Stop at 100 graticule fields, regardless of count.
7. Divide total end count by 2 to yield fiber count.

APPENDIX D. EQUIVALENT LIMITS OF DETECTION AND QUANTITATION

	fiber density on filter*		fiber concentration in air, f/cc	
	fibers per 100 fields	fibers/mm^2	400-L air sample	1000-L air sample
	200	255	0.25	0.10
	100	127	0.125	0.05
LOQ	80	102	0.10	0.04
	50	64	0.0625	0.025
	25	32	0.03	0.0125
	20	25	0.025	0.010
	10	12.7	0.0125	0.005
	8	10.2	0.010	0.004
LOD	5.5	7	0.00675	0.0027

* Assumes 385 mm^2 effective filter collection area, and field area = 0.00785 mm^2, for relatively "clean" (little particulate aside from fibers) filters.

ATTACHMENT 4

NIOSH Method 7402

ASBESTOS by TEM 7402

FORMULA: Various MW: Various CAS: Various RTECS: Various

METHOD: 7402 **EVALUATION: PARTIAL** **Issue 1: 15 May 1989**
Issue 2: 15 August 1994

OSHA : 0.1 asbestos fibers (>5 µm long)/cc; 1 f/cc/30 min excursion; carcinogen
MSHA: 2 asbestos fibers/cc
NIOSH: 0.1 f/cc (fibers > 5 µm long)/400 L; carcinogen
ACGIH: 0.2 crocidolite; 0.5 amosite; 2 chrysotile and other asbestos, fibers/cc; carcinogen

PROPERTIES: solid, fibrous, crystalline, anistropic

SYNONYMS [CAS#]: actinolite [77536-66-4] or ferroactinolite [15669-07-5]; amosite [12172-73-5]; anthophyllite [77536-67-5]; chrysotile [12001-29-5]; serpentine [18786-24-8]; crocidolite [12001-28-4]; tremolite [77536-68-6]; amphibole asbestos [1332-21-4].

SAMPLING

SAMPLER: FILTER (0.45- to 1.2-µm cellulose ester membrane, 25-mm diameter; conductive cassette)

FLOW RATE: 0.5 to 16 L/min

VOL-MIN*: 400 L @ 0.1 fiber/cc
-MAX*: (step 4, sampling)
*Adjust for 100 to 1300 fibers/mm^2

SHIPMENT: routine (pack to reduce shock)

SAMPLE STABILITY: stable

BLANKS: 2 to 10 field blanks per set

ACCURACY

RANGE STUDIED: 80 to 100 fibers counted

BIAS: not determined

OVERALL PRECISION ($\hat{S}_{rT}$): see EVALUATION OF METHOD

ACCURACY: not determined

MEASUREMENT

TECHNIQUE: MICROSCOPY, TRANSMISSION ELECTRON (TEM)

ANALYTE: asbestos fibers

SAMPLE PREPARATION: modified Jaffe wick

EQUIPMENT: transmission electron microscope; energy dispersive X-ray system (EDX) analyzer

CALIBRATION: qualitative electron diffraction; calibration of TEM magnification and EDX system

RANGE: 100 to 1300 fibers/mm^2 filter area [1]

ESTIMATED LOD: 1 confirmed asbestos fiber above 95% of expected mean blank value

PRECISION ($\hat{S}_r$): 0.28 when 65% of fibers are asbestos; 0.20 when adjusted fiber count is applied to PCM count [2].

APPLICABILITY: The quantitative working range is 0.04 to 0.5 fiber/cc for a 1000-L air sample. The LOD depends on sample volume and quantity of interfering dust, and is <0.01 fiber/cc for atmospheres free of interferences. This method is use d to determine asbestos fibers in the optically visible range and is intended to complement the results obtained by phase con trast microscopy (Method 7400).

INTERFERENCES: Other amphibole particles that have aspect ratios greater than 3:1 and elemental compositions similar to the asbestos minerals may interfere in the TEM analysis. Some non-amphibole minerals may give electron diffraction patterns similar to amphiboles. High concentrations of background dust interfere with fiber identification. Some non-asbestos amphibole m inerals may give electron diffraction patterns similar to asbestos amphiboles.

OTHER METHODS: This method is designed for use with Method 7400 (phase contrast microscopy).

REAGENTS:

1. Acetone. (See SPECIAL PRECAUTIONS.)

EQUIPMENT:

1. Sampler: field monitor, 25-mm, three-piece cassette with ca. 50-mm electrically-conductive extension cowl, cellulose ester membrane filter, 0.45- to 1.2-µm pore size, and backup pad.
   NOTE 1: Analyze representative filters for fiber background before use. Discard the filter lot if mean count is >5 fibers/100 fields. These are defined as laboratory blanks.
   NOTE 2: Use an electrically-conductive extension cowl to reduce electrostatic effects on fiber sampling and during sample shipment. Ground the cowl when possible during sampling.
   NOTE 3: 0.8-µm pore size filters are recommended for personal sampling. 0.45-µm filters are recommended for sampling when performing TEM analysis on the samples because the particles deposit closer to the filter surface. However, the higher pressure drop through these filters normally preclude their use with personal sampling pumps.
2. Personal sampling pump, 0.5 to 16 L/min, with flexible connecting tubing.
3. Microscope, transmission electron, operated at ca. 100 kV, with electron diffraction and energy-dispersive X-ray capabilities, and having a fluorescent screen with inscribed or overlaid calibrated scale (Step 15).
   NOTE: The scale is most efficient if it consists of a series of lines inscribed on the screen or partial circles every 2 cm distant from the center.
4. Diffraction grating replica with known number of lines/mm.
5. Slides, glass, pre-cleaned, 25- x 75-mm.
6. Knife, surgical steel, curved-blade.
7. Tweezers.
8. Grids, 200-mesh TEM copper, (optional: carbon-coated).
9. Petri dishes, 15-mm depth. The top and bottom of the petri dish must fit snugly together. To assure a tight fit, grind the top and bottom pieces together with an abrasive such as carborundum to produce a ground-glass contact surface.
10. Foam, clean polyurethane, spongy, 12-mm thick.
11. Filters, Whatman No. 1 qualitative paper or equivalent, or lens paper.
12. Vacuum evaporator.
13. Cork borer, (about 8-mm).
14. Pen, waterproof, marking.
15. Reinforcement, page, gummed.
16. Asbestos standard bulk materials for reference; e.g. SRM #1866, available from the National Institute of Standards and Technology.
17. Carbon rods, sharpened to 1 mm x 8 mm.
18. Microscope, light, phase contrast (PCM), with Walton-Beckett graticule (see method 7400).
19. Grounding wire, 22-gauge, multi-strand.
20. Tape, shrink- or adhesive-.

SPECIAL PRECAUTIONS: Acetone is extremely flammable (flash point = 0 °F). Take precautions not to ignite it. Heating of acetone must be done in a fume hood using a flameless, spark-free heat source. Asbestos is a confirmed human carcinogen. Handle only in a well-ventilated fume hood.

SAMPLING:

1. Calibrate each personal sampling pump with a representative sampler in line.
2. For personal sampling, fasten sampler to worker's lapel near worker's mouth. Remove the top cover from cowl extension ("open-face") and orient sampler face down. Wrap joint between extender and monitor body with tape to help hold the cassette together and provide a marking surface to identify the cassette. Where possible, especially at low %RH, attach sampler to electrical ground to reduce electrostatic effects during sampling.
3. Submit at least two field blanks (or 10% of the total samples, whichever is greater) for each set of samples. Remove top covers from the field blank cassettes and store top covers and cassettes in a clean area (e.g., closed bag or box) during sampling. Replace top covers when sampling is completed.
4. Sample at 0.5 to 16 L/min [3]. Adjust sampling rate, Q (L/min), and time, t (min), to produce fiber density, E, of 100 to 1300 fibers/mm ^{2} [$3.85 \cdot 10^4$ to $5 \cdot 10^5$ fibers per 25-mm filter with effective collection area (A_c = 385 mm^2)] for optimum accuracy. Do not exceed ca. 0.5 mg total dust loading on the filter. These variables are related to the action level (one-half the current standard), L (fibers/cc), of the fibrous aerosol being sampled by:

$$t = \frac{A_c \cdot E}{Q \cdot L \cdot 10^3}, \text{ min.}$$

   NOTE: The purpose of adjusting sampling times is to obtain optimum fiber loading on the filter. A sampling rate of 1 to 4 L/min for 8 h (700 to 2800 L) is appropriate in atmospheres containing ca. 0.1 fiber/cc in the absence of significant amounts of non-asbestos dust. Dusty atmospheres require smaller sample volumes (≤400 L) to obtain countable samples. In such cases take short, consecutive samples and average the results over the total collection time. For documenting episodic exposures, use high rates (7 to 16 L/min) over shorter sampling times. In relatively clean atmospheres, where targeted fiber concentrations are much less than 0.1 fiber/cc, use larger sample volumes (3000 to 10000 L) to achieve quantifiable loadings. Take care, however, not to overload the filter with background dust [3].
5. At the end of sampling, replace top cover and small end caps.
6. Ship samples upright with conductive cowl attached in a rigid container with packing material to prevent jostling or damage.
   NOTE: Do not use untreated polystyrene foam in the shipping container because electrostatic forces may cause fiber loss from sample filter.

SAMPLE PREPARATION:

7. Remove circular sections from any of three quadrants of each sample and blank filter using a cork borer [4]. The use of three grid preparations reduces the effect of local variations in dust deposit on the filter.
8. Affix the circular filter sections to a clean glass slide with a gummed page reinforcement. Label the slide with a waterproof marking pen.
   NOTE: Up to eight filter sections may be attached to the same slide.
9. Place the slide in a petri dish which contains several paper filters soaked with 2 to 3 mL acetone. Cover the dish. Wait 2 to 4 min for the sample filter(s) to fuse and clear.
   NOTE: The "hot block" clearing technique [5] of Method 7400 or the DMF clearing technique [6] may be used instead of steps 8 and 9.
10. Transfer the slide to a rotating stage inside the bell jar of a vacuum evaporator. Evaporate a 1-by 5-mm section of a graphite rod onto the cleared filter(s). Remove the slide to a clean, dry, covered petri dish [4].
11. Prepare a second petri dish as a Jaffe wick washer with the wicking substrate prepared from filter or lens paper placed on top of a 12-mm thick disk of clean, spongy polyurethane foam [7].

Cut a V-notch on the edge of the foam and filter paper. Use the V-notch as a reservoir for adding solvent.

NOTE: The wicking substrate should be thin enough to fit into the petri dish without touching the lid.

12. Place the TEM grid on the filter or lens paper. Label the grids by marking with a pencil on the filter paper or by putting registration marks on the petri dish halves and marking with a waterproof marker on the dish lid. In a fume hood, fill the dish with acetone until the wicking substrate is saturated.

NOTE: The level of acetone should be just high enough to saturate the filter paper without creating puddles.

13. Remove about a quarter section of the carbon-coated filter from the glass slide using a surgical knife and tweezers. Carefully place the excised filter, carbon side down, on the appropriately-labeled grid in the acetone-saturated petri dish. When all filter sections have been transferred, slowly add more solvent to the wedge-shaped trough to raise the acetone level as high as possible without disturbing the sample preparations. Cover the petri dish. Elevate one side of the petri dish by placing a slide under it (allowing drops of condensed acetone to form near the edge rather than in the center where they would drip onto the grid preparation).

CALIBRATION AND QUALITY CONTROL:

14. Determine the TEM magnification on the fluorescent screen:

a. Define a field of view on the fluorescent screen either by markings or physical boundaries.

NOTE: The field of view must be measurable or previously inscribed with a scale or concentric circles (all scales should be metric) [7].

b. Insert a diffraction grating replica into the specimen holder and place into the microscope. Orient the replica so that the grating lines fall perpendicular to the scale on the TEM fluorescent screen. Ensure that goniometer stage tilt is zero.

c. Adjust microscope magnification to 10,000X. Measure the distance (mm) between the same relative positions (e.g., between left edges) of two widely-separated lines on the grating replica. Count the number of spaces between the lines.

NOTE: On most microscopes the magnification is substantially constant only within the central 8- to 10-cm diameter region of the fluorescent screen.

d. Calculate the true magnification (M) on the fluorescent screen:

$$m = \frac{X \cdot G}{Y}$$

where: X = total distance (mm) between the two grating lines;
G = calibration constant of the grating replica (lines/mm);
Y = number of grating replica spaces counted

e. After calibration, note the apparent sizes of 0.25 and 5.0 µm on the fluorescent screen. (These dimensions are the boundary limits for counting asbestos fibers by phase contrast microscopy.)

15. Measure 20 grid openings at random on a 200-mesh copper grid by placing a grid on a glass slide and examining it under the PCM. Use the Walton-Beckett graticule to measure the grid opening dimensions. Calculate an average graticule field dimension from the data and use this number to calculate the graticule field area for an average grid opening.

NOTE: A grid opening is considered as one graticule field.

16. Obtain reference selected area electron diffraction (SAED) or microdiffraction patterns from standard asbestos materials prepared for TEM analysis.

NOTE: This is a visual reference technique. No quantitative SAED analysis is required [7]. Microdiffraction may produce clearer patterns on very small fibers or fibers partially obscured by other material.

a. Set the specimen holder at zero tilt.

b. Center a fiber, focus, and center the smallest field-limiting aperture on the fiber. Obtain a diffraction pattern. Photograph each distinctive pattern and keep the photo for comparison to unknowns.

NOTE: Not all fibers will present diffraction patterns. The objective lens current may need adjustment to give optimum pattern visibility. There are many more amphiboles which give diffraction patterns similar to the analytes named on p. 7402-1. Some, but not all, of these can be eliminated by chemical separations. Also, some non-amphiboles (e.g., pyroxenes, some talc fibers) may interfere.

17. Acquire energy-dispersive X-ray (EDX) spectra on approximately 5 fibers having diameters between 0.25 and 0.5 µm of each asbestos variety obtained from standard reference materials [7].

NOTE: The sample may require tilting to obtain adequate signal. Use same tilt angle for all spectra.

a. Prepare TEM grids of all asbestos varieties.

b. Use acquisition times (at least 100 sec) sufficient to show a silicon peak at least 75% of the monitor screen height at a vertical scale of ≥500 counts per channel.

c. Estimate the elemental peak heights visually as follows:

(1) Normalize all peaks to silicon (assigned an arbitrary value of 10).

(2) Visually interpret all other peaks present and assign values relative to the silicon peak.

(3) Determine an elemental profile for the fiber using the elements Na, Mg, Si, Ca, and Fe. Example: 0-4-10-3-<1 [7].

NOTE: In fibers other than asbestos, determination of Al, K, Ti, S, P, and F may also be required for fiber characterization.

(4) Determine a typical range of profiles for each asbestos variety and record the profiles for comparison to unknowns.

MEASUREMENT:

18. Perform a diffraction pattern inspection on all sample fibers counted under the TEM, using the procedures given in step 17. Assign the diffraction pattern to one of the following structures:

a. chrysotile;

b. amphibole;

c. ambiguous;

d. none.

NOTE: There are some crystalline substances which exhibit diffraction patterns similar to those of asbestos fibers. Many of these, (brucite, halloysite, etc.) can be eliminated from consideration by chemistry. There are, however, several minerals (e.g., pyroxenes, massive amphiboles, and talc fibers) which are chemically similar to asbestos and can be considered interferences. The presence of these substances may warrant the use of more powerful diffraction pattern analysis before positive identification can be made. If interferences are suspected, morphology can play an important role in making positive identification.

19. Obtain EDX spectra in either the TEM or STEM modes from fibers on field samples using the procedure of step 18. Using the diffraction pattern and EDX spectrum, classify the fiber:

a. For a chrysotile structure, obtain EDX spectra on the first five fibers and one out of ten thereafter. Label the range profiles from 0-5-10-0-0 to 0-10-10-0-0 as "chrysotile."

b. For an amphibole structure, obtain EDX spectra on the first 10 fibers and one out of ten thereafter. Label profiles ca. 0-2-10-0-7 as "possible amosite"; profiles ca. 1-1-10-0-6 as "possible crocidolite"; profiles ca. 0-4-10-3-<1 as "possible tremolite"; and profiles ca. 0-3-10-0-1 as "possible anthophyllite."

NOTE: The range of profiles for the amphiboles will vary up to ± 1 unit for each of the elements present according to the relative detector efficiency of the spectrometer.

c. For an ambiguous structure, obtain EDX spectra on all fibers. Label profiles similar to the chrysotile profile as "possible chrysotile." Label profiles similar to the various amphiboles as "possible amphiboles." Label all others as "unknown" or "non-asbestos."

20. Counting and Sizing:

a. Insert the sample grid into the specimen grid holder and scan the grid at zero tilt at low magnification (ca. 300 to 500X). Ensure that the carbon film is intact and unbroken over ca. 75% of the grid openings.

b. In order to determine how the grids should be sampled, estimate the number of fibers per grid opening during a low-magnification scan (500 to 1000X). This will allow the analyst to cover most of the area of the grids during the fiber count and analysis. Use the following rules when picking grid openings to count [7,8]:

(1) Light loading (<5 fibers per grid opening): count total of 40 grid openings.

(2) Moderate loading (5 to 25 fibers per grid opening): count minimum of 40 grid openings or 100 fibers.

(3) Heavy loading (>25 fibers per opening): count a minimum of 100 fibers and at least 6 grid openings.

Note that these grid openings should be selected approximately equally among the three grid preparations and as randomly as possible from each grid.

c. Count only grid openings that have the carbon film intact. At 500 to 1000X magnification, begin counting at one end of the grid and systematically traverse the grid by rows, reversing direction at row ends. Select the number of fields per traverse based on the loading indicated in the initial scan. Count at least 2 field blanks per sample set to document possible contamination of the samples. Count fibers using the following rules:

(1) Count all particles with diameter greater than 0.25 µm that meet the definition of a fiber (aspect ratio ≥3:1, longer than 5 µm). Use the guideline of counting all fibers that would have been counted under phase contrast light microscopy (Method 7400). Use higher magnification (10000X) to determine fiber dimensions and countability under the acceptance criteria. Analyze a minimum of 10% of the fibers, and at least 3 asbestos fibers, by EDX and SAED to confirm the presence of asbestos. Fibers of similar morphology under high magnification can be identified as asbestos without SAED. Particles which are of questionable morphology should be analyzed by SAED and EDX to aid in identification.

(2) Count fibers which are partially obscured by the grid as half fibers.
NOTE: If a fiber is partially obscured by the grid bar at the edge of the field of view, count it as a half fiber only if more than 2.5 µm of fiber is visible.

(3) Size each fiber as it is counted and record the diameter and length:

(a) Move the fiber to the center of the screen. Read the length of the fiber directly from the scale on the screen.
NOTE 1: Data can be recorded directly off the screen in µm and later converted to µm by computer.
NOTE 2: For fibers which extend beyond the field of view, the fiber must be moved and superimposed upon the scale until its entire length has been measured.

(b) When a fiber has been sized, return to the lower magnification and continue the traverse of the grid area to the next fiber.

d. Record the following fiber counts:

(1) f_s, f_b = number of asbestos fibers in the grid openings analyzed on the sample filter and corresponding field blank, respectively.

(2) F_s, F_b = number of fibers, regardless of identification, in the grid openings analyzed on the sample filter and corresponding field blank, respectively.

CALCULATIONS:

21. Calculate and report the fraction of optically visible asbestos fibers on the filter, $(f_s - f_b)/(F_s - F_b)$. Apply this fraction to fiber counts obtained by PCM on the same filter or on other filters for which the TEM sample is representative. The final result is an asbestos fiber count. The type of asbestos present should also be reported.
22. As an integral part of the report, give the model and manufacturer of the TEM as well as the model and manufacturer of the EDX system.

EVALUATION OF METHOD:

The TEM method, using the direct count of asbestos fibers, has been shown to have a precision of 0.275 (s_r) in an evaluation of mixed amosite and wollastonite fibers. The estimate of the asbestos fraction, however, had a precision of 0.11 (s_r). When this fraction was applied to the PCM count, the overall precision of the combined analysis was 0.20 [2].

REFERENCES:

[1] Walton, W. H. "The Nature, Hazards, and Assessment of Occupational Exposure to Airborne Asbestos Dust: A Review," Ann. Occup. Hyg., 25, 115-247 (1982).
[2] Taylor, D. G., P. A. Baron, S. A. Shulman and J. W. Carter. "Identification and Counting of Asbestos Fibers," Am. Ind. Hyg. Assoc. J. 45(2), 84-88 (1984).
[3] Johnston, A. M., A. D. Jones, and J. H. Vincent. "The Influence of External Aerodynamic Factors on the Measurement of the Airborne Concentration of Asbestos Fibers by the Membrane Filter Method," Ann. Occup. Hyg., 25, 309-316 (1982).
[4] Zumwalde, R. D. and J. M. Dement. Review and Evaluation of Analytical Methods for Environmental Studies of Fibrous Particulate Exposures, NIOSH Technical Information Bulletin #77-204 (1977).
[5] Baron, P. A. and G. C. Pickford. "An Asbestos Sample Filter Clearing Procedure," Appl. Ind. Hyg., 1:169-171,199 (1986).
[6] LeGuen, J. M. and S. Galvin "Clearing and Mounting Techniques for the Evaluation of Asbestos Fibers by the Membrane Filter Method" Ann. Occup. Hyg. 24, 273-280 (1981).
[7] Yamate, G., S. A. Agarwal, and R. D. Gibbons. "Methodology for the Measurement of Airborne Asbestos by Electron Microscopy," EPA Contract No. 68-02-3266 (in press).
[8] Steel, E. B. and J. A. Small. "Accuracy of Transmission Electron Microcopy for the Analysis of Asbestos in Ambient Environments," Anal. Chem., 57, 209-213 (1985).

METHOD REVISED BY:

Paul A. Baron, Ph.D.; NIOSH/DPSE.